

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/14/02

4:30:00 AM

ATC Group #: 8493

Analysis Date: 7/14/88

Project: NYC DEP, W&P# 1079.01.02

156 Williams Street, Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
03 8493 -1	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
04 8493 -2	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
05 8493 -3	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
06 8493 -4	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
07 8493 -5	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10079



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8493

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
156 Williams Street Roof

Date: Thursday, July 14, 1998

Time: 11:37:12 AM

Comments:

Number of Pages:

3
(including cover page)