

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

18 Vesey Street

Received: 7/19/02

8:30:00 AM

ATC Group #: 8539

Analysis Date: 7/19/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.3µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
001A 8539 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
002A 8539 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
003A 8539 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
004A 8539 -4	1440.00	0.0562	0	CHRYSTILE	1	0	0.0048	17.79	0.0048
005A 8539 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

228 East 46th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0530

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CONTACT: Nick Nolan

W&P FILE #: 1079-01-022

LABORATORY: ATC

CLIENT: NJC-DEP

PROJECT: Rooftop Cleanup

LOCATION: 18 Vesey St

ANALYSIS METHOD: PCM TEM
circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: N. Wells

8539

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
001A	Entrance to roof lot pending	3		4	4	08:30	14:30	360	1440	
002A	Entrance onto roof	3		4	4	08:31	14:31	360	1440	
003A	Northeast of roof	3		4	4	08:32	14:32	360	1440	
004A	Center area of roof	3		4	4	08:33	14:33	360	1440	
005A	Southeast of roof	3		4	4	08:34	14:34	360	1440	
006	Field	1								
007	Field	1								
008	Sealed	1								

COMMENTS:

SAMPLE BY: <u>N. Wells</u>	DATE: <u>7/18</u>
SIGNATURE: <u>Nick Wells</u>	
RELEASED BY: <u>N. Wells</u>	DATE: <u>7/19/02</u>
SIGNATURE: <u>Nick Wells</u>	
RECEIVED BY: <u>ATC</u>	DATE: <u>7/19/02</u>
SIGNATURE: <u>JD</u>	DATE: <u>8:30am</u>

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280

FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8539

Date: Friday, July 19, 2002

Client Project: NYC DEP. W&P# 1079.01.02
18 Vesey Street

Time: 2:51:23 PM

Comments:

Number of Pages: 3
(including cover page)