

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

W&P FILE #: 1079-01-02

CLIENT: NYC-DEP

CONTACT: Mike Nolte

PROJECT: 1079 Clean-up

LABORATORY: TEM AHERA EPA LEVEL II

LOCATION: 12-16 New York St

ANALYSIS METHOD: PCM 7400 TEM AHERA EPA LEVEL II

TECHNICIAN: N. Wells

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (mg/cc)
001A	Entrance below	3		10	10	08:10	10:30	150	1500	
002A	Entrance to roof area	3		10	10	10:01	10:31	150	1500	
003A	1st landing on stairs	3		10	10	08:02	10:32	150	1500	
004A	Top of stairs	3		10	10	08:03	10:33	150	1500	
005A	Center of roof	3		10	10	08:04	10:34	150	1500	
006	field	1								
007	field	1								
008	field	1								

COMMENTS:

SAMPLE BY: N. Wells	DATE: 7/25
SIGNATURE: [Signature]	
RELEASED BY: [Signature]	DATE: 7/26
SIGNATURE: [Signature]	
RECEIVED BY: [Signature]	DATE: 7/26
SIGNATURE: [Signature]	

SAMPLE TYPE CODES			
1 - Blank	2 - Pre-Abatement	3 - During Abatement	4 - During Glove Bag Removal
5 - Final Clearance (inside)	6 - Final Clearance (outside)	7 - Personal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

TESTWELL LABORATORIES, INC.
ENVIRONMENTAL DIVISION

PAGE 1 OF 1

DATE: 7/30/02

ASBESTOS LABORATORY

TEM AIR SUMMARY SHEET

CLIENT: **Warren & Panzer**PROJECT: NYC Dep/ Roof Clean-upMETHOD: AHERA

CLIENT NUMBER	LAB # 01 TEM -	VOLUME COLLECTED (L)	GRID OPENINGS ANALYZED	GRID AREA ANALYZED (mm ²)	COUNTABLE ASBESTOS STRUCTURES PER SAMPLE	CONCENTRATION (Structures/mm ²)	CONCENTRATION (Structures/cc)
001	5213	1500.0	5	0.061	0	< 16.53	< 0.004
002	5214	1500.0	5	0.061	0	< 16.53	< 0.004
003	5215	1500.0	5	0.061	1	16.53	0.004
004	5216	1500.0	5	0.061	0	< 16.53	< 0.004
005	5217	1500.0	5	0.061	0	< 16.53	< 0.004

	Structures/mm ²	Structures/cc
TOTAL AVERAGE CONCENTRATIONS	< 16.53	< 0.004

NOTE: When no asbestos structures are counted, the Analytical Sensitivity (Detection Limit) is reported.

COMMENTS: _____

ANALYST'S SIGNATURE: _____
