

Jul-17-02 12:52P

212 949 1273

P.03

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/16/02 3:20:00 PM
 ATC Group #: 8513
 Analysis Date: 7/17/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC- DEP, W&P# 1079.01.02
 26 Vesey Street.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
001A 8513 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
002A 8513 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
003A 8513 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
004A 8513 -4	1800.00	0.0450	0	CHRYSTILE	0	1	0.0048	22.24	0.0048
005A 8513 -5	1800.00	0.0450	0	CHRYSTILE	0	1	0.0048	22.24	0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 35% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Jul-17-02 12:53P

212 949 1273

P.04

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0530

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC-DEP

PROJECT: Roof Clean-up low level
LOCATION: 26 West St

W&P FILE # 1079.01.02

LABORATORY: JATC

ANALYSIS METHOD: PCM 7400

TECHNICIAN: 8513

TEM
AT-434A

TEM
EPA LEVEL II

CONTACT: Mike Nelson

PAGE 1 OF 1

P.O.

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (Hb./cc.)
001A	Entrance to landing	3		10	10	11:30	14:30	180	1800	
002A	Entrance to door of roof	3		10	10	11:31	14:31	180	1800	
003A	Cent area of roof	3		10	10	11:32	14:32	180	1800	
004A	Right side of roof	3		10	10	11:33	14:33	180	1800	
005A	Left side of roof	3		10	10	11:34	14:34	180	1800	
006	field	1								
007	field	1								
008	field	1								

COMMENTS:

SAMPLE BY: N. Nelson	DATE: 7/16/02
SIGNATURE: Mike Nelson	
RELEASED BY: JATC	DATE: 7/16/02
SIGNATURE: JATC	
RECEIVED BY: JATC	DATE: 7/16/02
SIGNATURE: JATC	

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

JUL-17-02 12:52P

212 949 1273

P.02



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8513

Fax #: (212) 922-0630

Client Project: NYC DEP, W&P# 1079.01.02
26 Vesey Street.

Date: Wednesday, July 17, 2002

Time: 9:18:13 AM

Comments:

Number of Pages: 3
(including cover page)