


ATHENICA

ENVIRONMENTAL SERVICES INC.

 Tel. (718) 794-7448
 Fax. (718) 794-8885

 CLIENT: Warren & Paez Engineering, P.C.
 LABORATORY ID #: T02-07-027
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.006643

 PROJECT: 45 Wall Street
 DATE OF REPORT: 07/27/02
 DATE OF ANALYSIS: 07/27/02
 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY
LABORATORY RESULTS

CLIENT #	LAB ID #	LOCATION	VOLUME (ft ³)	G.O.'s ANAL YZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (micrograms)	TOTAL ASBESTOS AIR CONC. (micrograms)	TOTAL ASBESTOS FILTER CONC. (micrograms)	AIR CONC. FOR STRUCT. 0.555-5.0um	AIR CONC. FOR STRUCT. 0.555-5.0um	ASBEST. TYPE CHRYB	AMPHIB. ASBEST. TYPE SPECIFY
1	T02-07-027-1079	Main roof east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
2	T02-07-027-1080	Main roof west	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
3	T02-07-027-1081	16 th floor east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
4	T02-07-027-1082	16 th floor west	1305	7	0.0605	0.0049	0.0049	16.53	0.0049	<0.0049	Chrys.	NA
5	T02-07-027-1083	Deck	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA

 ANALYST
 E. Sioukri

 LABORATORY DIRECTOR
 Spiro Doriganis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AESI) is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be stored for sixty (60) days. AESI Inc., should be notified within this time frame for a true duplicate analysis.
- If AESI Inc., did not conduct the sampling, this reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AESI Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

07/27/2002 11:43 FAX 718 784 4035

003

225 East 45th Street
New York, NY 10017
(212) 922-9077
Fax (212) 922-0330

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/s 12 hr⁺/s 6 hr⁺/s 3 hr⁺/s Immediate ⁺/s

W&P FILE #: 1079-01-02

CONTACT: BUNNY 97-479-2847

LABORATORY:

ANALYSIS METHOD: PCM TEM
7400 AHERA EPA LEVEL 1

TECHNICIAN: DAVID ECKENESILU

CLIENT: NYC DEP

PROJECT: 45 W 4th ST NY

LOCATION: 45 W 4th ST NY

702-07-027

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (µg/cc)	Ad. CONC. (µg/cc)
1	Main Roof East	3	1	3	3	0820	1545	4:25	1305	1.0049	46.5
2	" " West	3	2	3	3	0831	1546	4:35	1305	1.0049	46.5
3	16th floor East	3	3	3	3	0835	1550	4:35	1305	1.0049	46.5
4	" " West	3	4	3	3	0838	1551	4:35	1305	1.0049	46.5
5	Decon	3	5	3	3	0840	1555	4:35	1305	1.0049	46.5
6	fuel tank	1									

UNRECORDED

BY: DAVID ECKENESILU DATE: 7/26/02
TE: David
BY: DAVID ECKENESILU DATE: 7/26/02
David
E. Siaka DATE: 7/27/02
S

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

22:31 No. 002 P. 03

Sep 15.00

TEL:



ATHENICA

ENVIRONMENTAL SERVICES INC.
Tel: (718) 794-7490
Fax: (718) 794-4085

CLIENT: Warren & Panzer Engineers, P. C.
LABORATORY ID #: T02-07-024
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.D. AREA (mm²): 0.008643

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

PROJECT: 45 W 4th Street, NY
DATE OF REPORT: 07/26/02
DATE OF ANALYSIS: 07/26/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (L)	G.O.'s ANAL. YZND	AREA ANALY ZEN (mm ²)	ANALYT. SENSITV. (struc./cm ²)	TOTAL ASBESTOS AIR CONC. (struc./cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR STRUCT. 0.55-0.49um	AIR CONC. FOR STRUCT. >2.5-0.49um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPLCLFV
1	T02-07-024-1064	Main Roof East	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
2	T02-07-024-1065	Main Roof West	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
3	T02-07-024-1066	18 th Floor East	1305	7	0.0605	0.0049	0.0098	33.06	<0.0049	0.0098	Chrys.	NA
4	T02-07-024-1067	18 th Floor West	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
5	T02-07-024-1068	Decon	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA

[Signature]

ANALYST
E. Dimitrakas

[Signature] for 20

LABORATORY DIRECTOR
Spirin Demopoulos

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, FLAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a test duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported asbestos concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-8830**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC DEP
W&P FILE #: 1079-07-02
LABORATORY:

PROJECT: LLC 40 Rock Rose
LOCATION: 45 W. H. ST NY

LABORATORY:

ANALYSIS METHOD: PCM
circle one 7400

TECHNICIAN:

CONTACT: Benny/917-47-7812

PAGE _____ **OF** _____

20.

[illegible]

CONCLUSIONS

SAMPLE BY: <u>DAVID C. F. W. S. I. L.</u>	DATE: <u>7/25/02</u>
SIGNATURE: <u>Daniel</u>	
RELEASED BY: <u>DAVID C. F. W. S. I. L.</u>	DATE: <u>7/25/02</u>
SIGNATURE: <u>Daniel</u>	
RECEIVED BY: <u>C. Sigabro</u>	DATE: <u>7/26/02</u>
SIGNATURE: <u>[Signature]</u>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 764-7440

Fax. (718) 764-1845

CLIENT: Warren & Parzner Engineers, P.C.

LABORATORY ID #: T02-07-017

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.008643

PROJECT: NYC DEP, 45 Wall Street

DATE OF REPORT: 07/25/02

DATE OF ANALYSIS: 07/25/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (1000/1cm ²)	TOTAL ASBESTOS AIR CONC. (1000/1cm ²)	TOTAL ASBESTOS FILTER CONC. (1000/1cm ²)	AIR CONC. FOR STRAIGHT 0.355-5µm	AIR CONC. FOR STRAIGHT 0.355-5µm	ASBEST. TYPE CHRV.	AMPHIB. ASBEST. TYPE SPECIFY
1	T02-07-017-1029	Roof east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
2	T02-07-017-1030	Roof west	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
3	T02-07-017-1031	22 nd floor, roof east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
4	T02-07-017-1032	22 nd floor, roof west	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
5	T02-07-017-1033	Decon	1320	7	0.0605	0.0048	<0.0048	<16.53	NA	NA	NA	NA

 ANALYST
E. Dimitrakas

 LABORATORY DIRECTOR
Spiro Dougaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, FLAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling assistance will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a free duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test results may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.


ATHENICA

 ENVIRONMENTAL SERVICES INC.
 TEL (718) 784-7498
 FAX (718) 784-4085

 CLIENT: Warren & Pauzer Engineers, P.C.
 LABORATORY ID #: T02-07-017
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.008643

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 PROJECT: NYC DEP, 45 Wall Street
 DATE OF REPORT: 07/25/02
 DATE OF ANALYSIS: 07/25/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (L)	G.O.'s ANAL. VZK19	AREA ANALY. ZED (mm ²)	ANALYT. SENSITIV. (strut/cm ²)	TOTAL ASBESTOS AIR CONC. (strut/cm ²)	TOTAL ASBESTOS FILTER CONC. (strut/min)	AIR CONC. FOR STRUCT. 0.5SS-5µm	AIR CONC. FOR STRUCT. 5-20µm	ASBEST. TYPE CHRYS.	ANALYT. ASBEST. TYPE SIVELFV
1	T02-07-017-1029	Roof east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
2	T02-07-017-1030	Roof west	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
3	T02-07-017-1031	22 nd floor, roof east	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
4	T02-07-017-1032	22 nd floor, roof west	1305	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
5	T02-07-017-1033	Decon	1320	7	0.0605	0.0048	<0.0048	<16.53	NA	NA	NA	NA

 ANALYST
 E. Chaudhary

 LABORATORY DIRECTOR
 Sergio Dominguez

LABORATORY CERTIFICATION NUMBERS: NVLAP 181958, ELAP 10455

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

708-07-054


ATHENICA

ENVIRONMENTAL SERVICES INC.

 Tel. (718) 704-7400
 Fax. (718) 704-4085

 CLIENT: Warren & Pappert Engineers, P.C.
 LABORATORY ID #: T02-07-015
 ANALYT. METHODOLOGY: AHERA.
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.008643

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 PROJECT: NYC DEP, 45 Wall Street
 DATE OF REPORT: 07/24/02
 DATE OF ANALYSIS: 07/24/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (street/cm ²)	TOTAL ASBESTOS AIR CONC. (street/cm ²)	TOTAL ASBESTOS FILTER CONC. (street/cm ²)	AIR CONC. FOR STRICT. 0.55<5µm	AIR CONC. FOR STRICT. ≥2.5µm	ASBEST. TYPE CHYS.	AMPHIB. ASBEST. TYPE SPECIFY
1	T02-07-015-1019	Roof #1 East	1300	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
2	T02-07-015-1020	Roof #1 West	1300	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
3	T02-07-015-1021	Roof #1 South	1300	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
4	T02-07-015-1022	Roof #1 North	1300	7	0.0605	0.0049	<0.0049	<16.53	NA	NA	NA	NA
5	T02-07-015-1023	Roof #1 Center	1300	7	0.0605	0.0049	0.0049	16.53	<0.0049	0.0049	Chrys.	NA

 ANALYST
 E. Dimitrakas

 LABORATORY DIRECTOR
 Spiro Demargis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be issued for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
1	100	100	100	100	100
2	100	100	100	100	100
3	100	100	100	100	100
4	100	100	100	100	100
5	100	100	100	100	100
6	100	100	100	100	100
7	100	100	100	100	100
8	100	100	100	100	100
9	100	100	100	100	100
10	100	100	100	100	100
11	100	100	100	100	100
12	100	100	100	100	100
13	100	100	100	100	100
14	100	100	100	100	100
15	100	100	100	100	100
16	100	100	100	100	100
17	100	100	100	100	100
18	100	100	100	100	100
19	100	100	100	100	100
20	100	100	100	100	100
21	100	100	100	100	100
22	100	100	100	100	100
23	100	100	100	100	100
24	100	100	100	100	100
25	100	100	100	100	100
26	100	100	100	100	100
27	100	100	100	100	100
28	100	100	100	100	100
29	100	100	100	100	100
30	100	100	100	100	100
31	100	100	100	100	100
32	100	100	100	100	100
33	100	100	100	100	100
34	100	100	100	100	100
35	100	100	100	100	100
36	100	100	100	100	100
37	100	100	100	100	100
38	100	100	100	100	100
39	100	100	100	100	100
40	100	100	100	100	100
41	100	100	100	100	100
42	100	100	100	100	100
43	100	100	100	100	100
44	100	100	100	100	100
45	100	100	100	100	100
46	100	100	100	100	100
47	100	100	100	100	100
48	100	100	100	100	100
49	100	100	100	100	100
50	100	100	100	100	100
51	100	100	100	100	100
52	100	100	100	100	100
53	100	100	100	100	100
54	100	100	100	100	100
55	100	100	100	100	100
56	100	100	100	100	100
57	100	100	100	100	100
58	100	100	100	100	100
59	100	100	100	100	100
60	100	100	100	100	100
61	100	100	100	100	100
62	100	100	100	100	100
63	100	100	100	100	100
64	100	100	100	100	100
65	100	100	100	100	100
66	100	100	100	100	100
67	100	100	100	1	

CLIENT: DE P
W&P FILE #: 1079-01-02

PROJECT: NSA 10000 1-4-5

PROJECT: DECK ROOPS AND FACHS
LOCATION: 45 WALL ST
ANALYSIS METHOD: circle one
PCM 7400
TEM ANERA
TEM EPA LEVEL

TECHNICIAN: DAVID SCHNEFF

CONTACT: Benny 917-447-7815

510-70-015

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (µg/l)
01	Roof #1 East	3	1	4 4	1100 1625	325	1300	<16.53
02	" " West	3	2	4 4	1101 1626	325	1300	<16.53
03	" " South	3	3	4 4	1102 1627	325	1300	<16.53
04	" " North	3	4	4 4	1103 1628	325	1300	<16.53
05	" " Center	3	5	4 4	1104 1629	325	1300	<16.53
06	field blank	1						

COMMENTS:

SAMPLE BY: DAVID G. FENSTERMAKER	DATE: 7/28/68
SIGNATURE: [Signature]	
RELEASED BY: DAVID G. FENSTERMAKER	DATE: 7/28/68
SIGNATURE: [Signature]	
RECEIVED BY: G. FENSTERMAKER	DATE: 7/23/68
SIGNATURE: [Signature]	92:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0638**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /g	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
1	100	100	100	100	100
2	100	100	100	100	100
3	100	100	100	100	100
4	100	100	100	100	100
5	100	100	100	100	100
6	100	100	100	100	100
7	100	100	100	100	100
8	100	100	100	100	100
9	100	100	100	100	100
10	100	100	100	100	100
11	100	100	100	100	100
12	100	100	100	100	100
13	100	100	100	100	100
14	100	100	100	100	100
15	100	100	100	100	100
16	100	100	100	100	100
17	100	100	100	100	100
18	100	100	100	100	100
19	100	100	100	100	100
20	100	100	100	100	100
21	100	100	100	100	100
22	100	100	100	100	100
23	100	100	100	100	100
24	100	100	100	100	100
25	100	100	100	100	100
26	100	100	100	100	100
27	100	100	100	100	100
28	100	100	100	100	100
29	100	100	100	100	100
30	100	100	100	100	100
31	100	100	100	100	100
32	100	100	100	100	100
33	100	100	100	100	100
34	100	100	100	100	100
35	100	100	100	100	100
36	100	100	100	100	100
37	100	100	100	100	100
38	100	100	100	100	100
39	100	100	100	100	100
40	100	100	100	100	100
41	100	100	100	100	100
42	100	100	100	100	100
43	100	100	100	100	100
44	100	100	100	100	100
45	100	100	100	100	100
46	100	100	100	100	100
47	100	100	100	100	100
48	100	100	100	100	100
49	100	100	100	100	100
50	100	100	100	100	100
51	100	100	100	100	100
52	100	100	100	100	100
53	100	100	100	100	100
54	100	100	100	100	100
55	100	100	100	100	100
56	100	100	100	100	100
57	100	100	100	100	100
58	100	100	100	100	100
59	100	100	100	100	100
60	100	100	100	100	100
61	100	100	100	100	100
62	100	100	100	100	100
63	100	100	100	100	100
64	100	100	100	100	100
65	100	100	100	100	100
66	100	100	100	100	100
67	100	100	100	1	

CLIENT: DEP
W&P FILE #: 1079-01-02

LABORATORY:

PROJECT: DEP ROOPS AND FACADE ANALYSIS METHOD: PCM
LOCATION: 45 WALL ST circle one

TECHNICIAN: David for class!!

CONTACT: Penny 917-417-5781

570-70-601

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (mg/l)
01	Roof #1 east	3	1	4 4	1100 1625	325	1300	<16.53
02	" " west	3	2	4 4	1101 1626	325	1300	<16.53
03	" " south	3	3	4 4	1102 1627	325	1300	<16.53
04	" " North	3	4	4 4	1103 1628	325	1300	<16.53
05	" " Center	3	5	4 4	1104 1629	325	1300	<16.53
06	fuel tank	1						

SAMPLE BY: DAVID GEFENBERG	DATE: 7/28/02
SIGNATURE: David	
RELEASED BY: DAVID GEFENBERG	DATE: 7/28/02
SIGNATURE: David	
RECEIVED BY: E. GIBLIN	DATE: 7/23/02
SIGNATURE: E	22:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE FOR END ANALYSIS INFORMATION