

FIBER CONTROL, INC.

3010 BURNS AVENUE
WANTAGH, NY 11793
(516) 781-3000
FAX (516) 781-3085

INVOICE**09/25/02****F1168**

Date:

Inv. No.: **1**

Due Date:

Page No.:

**BILL TO: New York City Dept of
Environmental Protection
Asbestos Control Program
59-17 Junction Blvd
Flushing, NY 11373-5108
Att: Alphonso Plumptre
Deputy Lab Director Supervising I.H.**

JOB SITE: job sites listed below

REFERENCE

TERMS

YOUR #

OUR #

SALES REP

TEL: 718-595-3671**Upon Completion****CONTRACT ROF-REM1****F1168****PG**

DESCRIPTION				UNIT MEASURE		QUANTITY		UNIT PRICE		EXTENDED PRICE	
REFERENCE								ITEM DISCOUNT			
Exterior Cleanup											
Address		Asphalt Roof		Unit Price	façade		Unit Price	Gravel Roof		Unit Price	Total
22 Warren Street		roof	2500 sq ft	@ 1.48	2250 sq ft		@ 2.50				3,700.00
		façade									5,625.00
12-16 Vesey Street		façade			3375 sq ft		@ 2.50				8,437.50
		gravel roof						3450 sq ft @ 2.98			10,281.00
		3rd setback	552 sq ft	@ 1.48							816.96
		back setback	544 sq ft	@ 1.48							805.12
		2nd fl setback	510 sq ft	@ 1.48							754.80
		1st fl setback	200 sq ft	@ 1.48							296.00
56-58 Warren Street		roof	4500 sq ft	@ 1.48	3275 sq ft		@ 2.50				6,660.00
		façade									8,187.50
116 Chambers Street		façade			1875 sq ft		@ 2.50				4,687.50
5-7 Dey Street		1st fl (awnings)			780 sq ft		@ 2.50				1,950.00
57 Murray Street		façade			1260 sq ft		@ 2.50				3,150.00
		roof	1680 sq ft	@ 1.48							2,486.40
59 Murray Street		façade			780 sq ft		@ 2.50				1,950.00
		roof	2160 sq ft	@ 1.48							3,196.80
											62,984.58

WWW.ACTIONHAZMAT.COM

SUB TOTAL
TAX
TOTAL

\$ **62,984.58**
0.00
\$ **62,984.58**

NET TO PAY

E154 WTC

ONLY
TYPEWRITTEN
FORMS WILL BE
ACCEPTED



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION
Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Corona, NY 11368-5107

**ASBESTOS PROJECT NOTIFICATION
(ASBESTOS INSPECTION REPORT)**

Rel 1483 MNO2
Building Dept or TRU No
FOR OFFICIAL USE ONLY

1. NYC DEP
(See fee schedule)

When submitting this form at the NYC Department of Buildings, the original form and three (3) copies with original signatures are required. Submittal at the NYCDEP requires one copy of the form with original signatures. This form must be submitted to the NYC DEP not less than one week in advance of the start of abatement activities.

I. FACILITY

2. Address 22 WARREN STREET Borough N.Y. Zip 10007
AKA _____ 3. Block 135 4. Lot 10
5. Type of Facility _____ 6. Name of Building _____

II. BUILDING OWNER

7. Name 22 WARREN GROUP LLC 8. Contact Person _____
9. Tel. # _____ Fax # _____
10. Address 331 MADISON AVE City N.Y. State N.Y. Zip 10017

III. GENERAL CONTRACTOR

11. Name _____ Tel. # _____

IV. ASBESTOS ABATEMENT CONTRACTOR

12. Name FIBER CONTROL 13. Contact Person TONY COSTA
14. Federal Employer ID. # PII 15. Tel. # 516-781-3000 Fax # 516-781-3085
16. Address 3010 BURNS AVE City WANTASH State NY Zip 11793

V. THIRD PARTY AIR MONITOR

17. Name WARREN & PANZER ENGINEERS, PC 18. Contact Person MICHAEL NOLAN
19. Federal Employer ID. # _____ 20. Tel. # 212-922-0077 Fax # 212-922-0630
21. Address 228 EAST 45TH STREET City NEW YORK State NY Zip 10017
22. Sample Analysis Laboratory SCIENTIFIC LABORATORIES, LLC 23. NYS DOH ELAP # 11480

VI. PROJECT INFORMATION

24. Starting date for this portion of work 9/13/02 Projected completion date 10/13/02

Asbestos work schedule ☐ Monday ☐ Tuesday ☐ Wednesday ☐ Thursday ☐ Friday ☐ Saturday ☐ Sunday


Shift from: _____ ☐ am ☐ pm to _____ ☐ am ☐ pm

If other,
specify _____

Access to inspect the premises must be provided during the work schedule indicated in this item.

25. Total amount of asbestos-containing material to be abated during this work

4750 Square Feet, and/or _____ Linear Feet



ACP 7
2/2001

U.S.P.
BUREAU OF ENVIRONMENTAL
REGULATION & ENFORCEMENT
ASBESTOS CONTROL
PROGRAM
TRU 1

09/16/2002 16:45 FAX 718 784 4085

012

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P.C.
 LABORATORY ID #: T02-09-049
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.013771

PROJECT: NYC DEP, 22 Warren St.
 DATE OF REPORT: 09/15/02
 DATE OF ANALYSIS: 09/15/02
 EFFECTIVE FILTER AREA (mm²): 385

ATHENICA
 ENVIRONMENTAL SERVICES INC.
 Tel. (718) 784-7400
 Fax. (718) 784-4085

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (street/cm ³)	TOTAL ASBESTOS AIR CONC. (street/cm ³)	TOTAL ASBESTOS FILTER CONC. (street/cm ³)	AIR CONC. FOR STRUCT. 0.558-5um	AIR CONC. FOR STRUCT. ≥5.0um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-09-049-2312	Inside work area South	1440	4	0.0551	0.0049	<0.0049	<18.15	NA	NA	NA	NA
02	T02-09-049-2313	Inside work area East	1440	4	0.0551	0.0049	<0.0049	<18.15	NA	NA	NA	NA
03	T02-09-049-2314	Inside work area Center	1440	4	0.0551	0.0049	<0.0049	<18.15	NA	NA	NA	NA
04	T02-09-049-2315	Inside work area West	1440	4	0.0551	0.0049	<0.0049	<18.15	NA	NA	NA	NA
05	T02-09-049-2316	Inside work area North	1440	4	0.0551	0.0049	<0.0049	<18.15	NA	NA	NA	NA

ANALYST
 G. S. S. S.

LABORATORY DIRECTOR
 Spiro Donagis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

2228 East 45th Street
New York, NY 10017
(212) 822-0077
Fax (212) 822-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

W&P FILE #: 1079: 01, 02

CLIENT: NY DEP
PROJECT: FACADES
LOCATION: 22 WARREN ST.

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM TEM

circle one
7400
ANLEBA EPA LEVEL II

TECHNICIAN: CELESTINE NMGRCA

PAGE 1 OF 1

Q.

CONTACT: MR Mike

[illegible]

CONCLUSION

650-60-701

SAMPLE BY: CECILIA N M D L K R DATE: 09/14/12

SIGNATURE: *[Signature]*

RELEASED BY: SP-8 J. J. [illegible] DATE: 5/14/68

RELEASED BY: SP-5 J. J. [illegible] DATE: 11/1/77
SIGNATURE: [Signature]

SIGNATURE: SAFFORD DATE: 9/12/73

RECEIVED BY: ACN-TLM

RECEIVED BY: TECHNICAL DATE: 11/5/84

SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ASBESTOS INSPECTION REPORT

REMISE NO.		STREET				INSPECTION DATE	
22		Warren Street				9/14/02	
DOOR	ZIP	BORO CODE	BLOCK	LOT	SQUAD #	BADGE #	
R/F	10007	1	135	10	1	AD10	
INSPECTOR		BLDG TYPE	BASIS OF INSPECT.			PHOTOS TAKEN YES/NO	
ALPHONSO PLUMPTRE			TRU1483MN02				
CONTRACTORS NAME				SAMPLE NO.			
FIBER CONTROL							
ADDRESS				SAMPLE NO.			
3010 BURNS AVE CITY WANTAGH							
STATE N.Y ZIP 11793				SAMPLE NO.			
PHONE 516 781-3000							
LABORATORY NAME				OWNERS NAME			
WARREN & PANZER ENGINEERS, PC				22, Warren Group LLC			
ADDRESS				ADDRESS			
228 E. 45TH ST CITY N.Y				331, Madises Ave CITY N.Y			
STATE N.Y ZIP 10017				STATE N.Y ZIP 10017			
PHONE 922-0077				PHONE			
CONTACT PERSON:				TIME OF INSPECTION FROM: 7:50 am/pm TO: 4:30 am/pm			
INSPECTION DISCLOSED:							

The facade and the roof were cleaned simultaneously. The Contractor have to use bucket truck to lower the handlers on to the roof due to inaccessible of the roof.

Both roof and facade were cleaned and no visible debris observed after the cleanup.

WTC debris was also found at the rear setback on the 2nd floor. The setback was cleaned and no visible debris observed after cleanup.

NOV #	INFRACTIONS					RESULT CODE
						5
NOV #						SUPERVISORS INITIALS
						PPP

BORO 1 - MANHATTAN 2 - BRONX 3 - BROOKLYN 4 - QUEENS 5 - RICHMOND

BLDG TYPE A > 6 Stories B < 6 Stories C Single Family
D School E Hospital F Public Owned Property

RESULT CODES 1 - Violation Issued 2 - No Violations Issued 3 - No Access
4 - Project not Started (No NOV) 5 - Project Completed (No NOV)

ACP 309

FILE