

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

26 Warren Street

Received: 7/13/02

7:15:00 PM

ATC Group #: 8489

Analysis Date: 7/14/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8489 -1	2160.00	0.0450	0	None Detected	0	0.0040	<22.24	<0.0040	
02 8489 -2	2160.00	0.0450	0	None Detected	0	0.0040	<22.24	<0.0040	
03 8489 -3	2160.00	0.0450	0	None Detected	0	0.0040	<22.24	<0.0040	
04 8489 -4	2160.00	0.0450	0	None Detected	0	0.0040	<22.24	<0.0040	
05 8489 -5	2160.00	0.0450	0	None Detected	0	0.0040	<22.24	<0.0040	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101157-0, NY State ELAP #10379

2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

Q

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
--	-----------------------	-----------------------	----------------------	----------------------	---------------------------

WRP FILE #:

CONTACT:

CLIENT: Nyc DEP
PROJECT: 26 Warren Street
LOCATION: 26 Warren St Roof & Facade

LABORATORY: _____
ANALYSIS METHOD: PCM 7400
circle one
TECHNICIAN: Jeffrey
TEM
AHERA
EPA LEVEL II
Amount

LABORATORY: _____

ANALYSIS METHOD: _____

PCM TEM PCM TEM
7400 AHERA EPA LEVEL II

TECHNICIAN *Jeffrey E. Anderson*

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE	TIME	TOTAL TIME	VOLUME (liters)	CONCENTR. (mg/cc.)
				START	STOP	ON	OFF	
01	Right Side of sidewalk	3		12	12	15:30	18:30	1800
02	Left Side of sidewalk	3		12	12	15:32	18:32	
03	Center of building	3		12	12	15:33	18:33	
04	Left side of bldg	3		12	12	15:34	18:34	
05	Right side of bldg	3		12	12	15:35	18:35	
06	{Front}	1						
07	{Back}	1						

COMMENTS:

SAMPLE BY: CHITRAM RAMRAJ DATE: 07/11/02
SIGNATURE: Chitram Ramraj
RELEASED BY: _____ DATE: _____
SIGNATURE: _____
RECEIVED BY: ATC DATE: 07/13/02
SIGNATURE: H. G. Rao 19.15

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

OFF REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panger Engineers, P.C.

Fax #: (212) 922-0630

Date: Thursday, July 14, 1988

Time: 10:41:14 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8489

Client Project: NYC DEP. W&P# 1079.01.02
26 Warren Street

Number of Pages: 3
(including cover page)