

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/20/02 1:00:00 PM
 ATC Group #: 8555
 Analysis Date: 7/21/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
 54 Warren Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Analytical		Asbestos		Notes
					# Structures 0.5µ-5µ	Sensitivity 5µ (S/cc)	Concentration (S/mm²)	(S/cc)	
001A 8555 -1	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
002A 8555 -2	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
003A 8555 -3	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
004A 8555 -4	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
005A 8555 -5	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10876

226 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P.C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

8555

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: ANC-DEP

W&P FILE #: 60790102

LABORATORY: NYC

CONTACT: *M. Nola*

PROJECT: facade cleaning

ANALYSIS METHOD: PCM TEM TEM

LLW#:

LOCATION: 54 Warren St

circle one 7400 NAEBA EPA LEVEL II

SCA JOB#:

TECHNICIAN:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
001A	Center of area - street	3		10 10	07:30 09:50	140	1400	
002A	Right side of bldg	3		10 10	07:31 09:51	140	1400	
003A	Right side of bldg - street	3		10 10	07:52 09:52	140	1400	
004A	Right side of bldg	3		10 10	07:53 09:53	140	1400	
005A	Right side of bldg - street	3		10 10	07:54 09:54	140	1400	
006	Field	1						
007	Field	1						
008	Sealed	1						

COMMENTS: Bl down area near lot

SAMPLE BY: *J. J. J.* DATE: 7/20

SIGNATURE: *J. J. J.*

RELEASED BY: *ATC* DATE: 7/20

SIGNATURE: *ATC*

RECEIVED BY: *ATC* DATE: 7/20

SIGNATURE: *ATC*

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8555

Date: Sunday, July 21, 2002

Client Project: NYC DEP, W&P# 1079.01.02
54 Warren Street

Time: 8:44:21 AM

Comments:

Number of Pages: 3
(including cover page)

25