

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/12/02 3:45:00 PM
 ATC Group #: 8450
 Analysis Date: 7/12/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
 53 Warren Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
001A 8450 -1	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046	
002A 8450 -2	1500.00	0.0562	0	CHRYSTOLE	1 0	0.0046	17.79	0.0046	
003A 8450 -3	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046	
004A 8450 -4	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046	
005A 8450 -5	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0530

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

PAGE 1 OF 1

W&P FILE #: 1077-01-02

CLIENT: NYC-DEP

LABORATORY: ATC

CONTACT: Mike Nolan

PROJECT: Roof Area - Champ

ANALYSIS METHOD: PCM 7400
circle one

LLW#:

LOCATION: 53 Warren St

TECHNICIAN: 8450

SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (Hb./cc.)
001A	Entrance to bldg	3		10	10	07:30	10:00	150	1500	
002A	Entrance to roof	3		10	10	07:34	10:01	150	1500	
003A	3' ady to sky light	3		10	10	07:32	10:02	150	1500	
004A	lydside of roof	3		10	10	07:33	10:03	150	1500	
005A	right side of roof	3		10	10	07:34	10:04	150	1500	
006	Field Blank	1								
007	Field Blank	1								
008	Sealed Blank	1								

COMMENTS:

SAMPLE BY: Terry Wells	DATE: 7/11
SIGNATURE: Terry Wells	DATE: 7/11
RELEASED BY: Terry Wells	DATE: 7/11/02
SIGNATURE: Terry Wells	DATE: 7/11/02
RECEIVED BY: ATC	DATE: 7/11/02
SIGNATURE: JD	DATE: 7/11/02

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8450

Date: Friday, July 12, 2002

Client Project: NYC DEP. W&P# 1079.01.02
53 Warren Street

Time: 10:00:12 AM

Number of Pages:

3

Comments:

(including cover page)