



ASBESTOS REMOVAL CORP.

14-20 129th Street
College Point, New York 11356
(718) 961-4100 • Fax # (718) 961-4103

NYC DEP
PROJECT 90 WASHINGTON STREET
NEW YORK, NY

CONTRACT# ROF-REM3
INVOICE # 48
DATE 11/27/2002

ITEM#	DESCRIPTION OF ITEM	UNIT PRICE	TY/SQ. FT.	TOTAL VALUE
1	Roof cleanup-Asphalt/Uncovered Surface up to 2500 sq. ft. of clean-up per bldg/structure	\$ 1.00	0	\$ -
2	Roof cleanup-Asphalt/Uncovered Surface between 2500 sq. ft.5000 sq. ft.	\$ 0.85	0	\$0.00
3	Roof cleanup-Asphalt/Uncovered Surface greater than 5000 sq. ft.	\$ 0.80	0	\$ -
4	Roof cleanup-Gravel/Stone Surface up to 2500 sq. ft. of clean-up per bldg/structure	\$ 3.00	0	\$ -
5	Roof cleanup-Gravel/Stone Surface between 2500 sq. ft.and 5000 sq. ft.	\$ 2.75	0	0
6	Roof cleanup-Gravel/Stone Greater than 5000 Sq. FT.	\$ 2.50	11809	29522.5
7	Façade Clean-up (up to 5000 sq. ft.)	\$ 2.60	0	\$ -
8	Façade Clean-up (6-15 Story Buildings) (greater than 5000 sq. ft.	\$ 2.45	0	\$ -
TOTAL				\$ 29,522.50

R. Radman
Sent to Denise
1-17-03

E214651

EMERGENCY
ONLY
PERMIT TEN
FORMS WILL BE
ACCEPTED



NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION

Asbestos Control Program
59-17 Junction Boulevard, 8th Floor, Corona, NY 11368-5107

ASBESTOS PROJECT NOTIFICATION
(ASBESTOS INSPECTION REPORT)

TRU 1789MN02
Building Dept. or TRU No
FOR OFFICIAL USE ONLY
N.Y.C. DE
1. (See fee schedule)

When submitting this form at the NYC Department of Buildings, the original form and three (3) copies with original signatures are required. Submittal at the NYCDEP requires one copy of the form with original signatures. This form must be submitted to the NYC DEP not less than one week in advance of the start of abatement activities.

I. FACILITY

2. Address 90 WASHINGTON STREET Borough Manhattan Zip _____
AKA 52-54 WEST STREET/23-31 RECTOR STREET 3. Block _____ 4. Lot _____
5. Type of Facility _____ 6. Name of Building _____

II. BUILDING OWNER

7. Name ZAR REALTY MGMT. CORP 8. Contact Person Yevgeniy L
9. Tel. # (212) 971-0111 Fax # _____
10. Address 384, 5th Ave City NYC State NY Zip 10018

III. GENERAL CONTRACTOR

11. Name _____ Tel. # _____

IV. ASBESTOS ABATEMENT CONTRACTOR

12. Name TRIO ASBESTOS REMOVAL CORP. 13. Contact Person STEVEN PARMIGIANI
14. Federal Employer ID. # PII 15. Tel. # (718) 961-4100 Fax # (718) 961-4103
16. Address 14-20 129 STREET City COLLEGE POINT State NY Zip 11356

V. THIRD PARTY AIR MONITOR

17. Name WARREN & PANZER ENGINEERS, P.C. 18. Contact Person MIKE NOLAN
19. Federal Employer ID. # _____ 20. Tel. # (212) 922-0077 Fax # (212) 922-0630
21. Address 228 EAST 45 STREET City NEW YORK State NY Zip 10017
22. Sample Analysis Laboratory WARREN & PANZER ENG., P.C. 23. NYS DOH ELAP # 11251

VI. PROJECT INFORMATION

24. Starting date for this portion of work 10/29/02 Projected completion date 11/10/02

Asbestos work schedule ☒ Monday ☒ Tuesday ☒ Wednesday ☒ Thursday ☒ Friday ☒ Saturday ☒ Sunday


Shift from: 8:00 ☒ am ☐ pm to 8:00 ☐ am ☒ pm

If other,
specify _____

Access to inspect the premises must be provided during the work schedule indicated in this item.

25. Total amount of asbestos-containing material to be abated during this work

11,809 Square Feet, and/or 0 Linear Feet



ACF
2/20



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel: (718) 794-7400
Fax: (718) 794-4005

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-011

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

PROJECT: NYC DEP, 90 Washington Street

DATE OF REPORT: 1/03/02

DATE OF ANALYSIS: 1/03/02

EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (M)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (femtograms)	TOTAL ASBESTOS AIR CONC. (40mc/ft ³)	TOTAL ASBESTOS FILTER CONC. (40mc/ft ³)	AIR CONC. FOR STRUCT. 0.55-5.0um	AIR CONC. FOR STRUCT. 9.5-10um	ASBEST. TYPE CHYAS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-11-011-3730	By the decon	1520	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
02	T02-11-011-3731	Inside work area south	1520	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
03	T02-11-011-3732	Inside work area east	1520	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
04	T02-11-011-3733	Inside work area west	1520	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
05	T02-11-011-3734	Inside work area north	1520	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA

E. Dimitrakas

ANALYST
E. Dimitrakas

Spino Dongaris

LABORATORY DIRECTOR
Spino Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 191958, ELAP 10955

- Athenica Environmental Services Inc. (AES) is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to those tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced.
- except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc., with respect to the services charged, shall in no event exceed the amount of the invoice.

2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1079:01:02

LABORATORY: A742N(CA

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	AHERA	EPA LEVEL II

TECHNICIAN: Coleston
Names:

CONTACT: Mr MICE No 129

PAGE 1 OF 1

20.

COMMENTS:

SAMPLE NO. 1015 DATE: 11/2/83

SIGNATURE: BW

RELEASED BY: COLLEEN NIMES DATE: 11/2/01

SIGNATURE: C. J. [Signature]

RECEIVED BY: A. C. TIGAL DATE: 11/3/52

102-11011

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel: (718) 794-7400

Fax: (718) 794-0065

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-008

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

PROJECT: NYC DEP, 90 Washington Street

DATE OF REPORT: 11/02/02

DATE OF ANALYSIS: 11/02/02

EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB ID #	LOCATION	VOLUME (ft ³)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (fibers/cm ³)	TOTAL ASBESTOS AIR CONC. (fibers/cm ³)	TOTAL ASBESTOS FILTER CONC. (fibers/cm ³)	AIR CONC. FOR STRUCT. 0.55-5.0um	AIR CONC. FOR STRUCT. 5.0-10um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-11-008-3715	By the decon	1650	4	0.0537	0.0043	<0.0043	<18.61	NA	NA	NA	NA
02	T02-11-008-3716	By the entrance of work area	1650	4	0.0537	0.0043	<0.0043	<18.61	NA	NA	NA	NA
03	T02-11-008-3717	Inside work area south	1650	4	0.0537	0.0043	0.0043	18.61	<0.0043	0.0043	Chrys.	NA
04	T02-11-008-3718	Inside work area center	1650	4	0.0537	0.0043	<0.0043	<18.61	NA	NA	NA	NA
05	T02-11-008-3719	Inside work area north	1650	4	0.0537	0.0043	<0.0043	<18.61	NA	NA	NA	NA

ANALYST
E. Dimitrakas

LABORATORY DIRECTOR
Spiro Dourgaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be entered for study (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to current period. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

11/07/2002 18:14 FAX

016

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel: (718) 764-7490

Fax: (718) 764-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-032

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

PROJECT: NYC DEP, 90 Washington Street

DATE OF REPORT: 11/06/02

DATE OF ANALYSIS: 11/06/02

EFFECTIVE FILTER AREA (mm²): 385**LABORATORY RESULTS**

CLIENT #	LAB ID #	LOCATION	VOLUME (l)	G.O. % ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (fibre/cm ³)	TOTAL ASBESTOS AIR CONC. (fibre/cm ³)	TOTAL ASBESTOS FILTER CONC. (fibre/cm ³)	AIR CONC. FOR STRUCT. 0.5 <= < 5 µm	AIR CONC. FOR STRUCT. > 5.0 µm	ASBEST. TYPE CHRYS.	AMPHIB. TYPE SPECIFY
01	T02-11-032-3861	In decon clean rm	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA
02	T02-11-032-3862	Staircase roof entrance	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA
03	T02-11-032-3863	West side of roof	1440	4	0.0537	0.0050	SAMPLE OVERLOADED WITH PARTICULATE MATERIAL RENDERING IT UNACCEPTABLE FOR ANALYSIS					
04	T02-11-032-3864	South side of roof	1440	4	0.0537	0.0050	SAMPLE OVERLOADED WITH PARTICULATE MATERIAL RENDERING IT UNACCEPTABLE FOR ANALYSIS					
05	T02-11-032-3865	South west roof	1440	4	0.0537	0.0050	SAMPLE OVERLOADED WITH PARTICULATE MATERIAL RENDERING IT UNACCEPTABLE FOR ANALYSIS					

ANALYST

E. Dimitrakas

LABORATORY DIRECTOR

Spiro Doogaris

LABORATORY CERTIFICATION REQUIREMENTS: NY 11-0117.30, 11-0117.31, 11-0117.32

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
1	100	100	100	100	100
2	100	100	100	100	100
3	100	100	100	100	100
4	100	100	100	100	100
5	100	100	100	100	100
6	100	100	100	100	100
7	100	100	100	100	100
8	100	100	100	100	100
9	100	100	100	100	100
10	100	100	100	100	100
11	100	100	100	100	100
12	100	100	100	100	100
13	100	100	100	100	100
14	100	100	100	100	100
15	100	100	100	100	100
16	100	100	100	100	100
17	100	100	100	100	100
18	100	100	100	100	100
19	100	100	100	100	100
20	100	100	100	100	100
21	100	100	100	100	100
22	100	100	100	100	100
23	100	100	100	100	100
24	100	100	100	100	100
25	100	100	100	100	100
26	100	100	100	100	100
27	100	100	100	100	100
28	100	100	100	100	100
29	100	100	100	100	100
30	100	100	100	100	100
31	100	100	100	100	100
32	100	100	100	100	100
33	100	100	100	100	100
34	100	100	100	100	100
35	100	100	100	100	100
36	100	100	100	100	100
37	100	100	100	100	100
38	100	100	100	100	100
39	100	100	100	100	100
40	100	100	100	100	100
41	100	100	100	100	100
42	100	100	100	100	100
43	100	100	100	100	100
44	100	100	100	100	100
45	100	100	100	100	100
46	100	100	100	100	100
47	100	100	100	100	100
48	100	100	100	100	100
49	100	100	100	100	100
50	100	100	100	100	100
51	100	100	100	100	100
52	100	100	100	100	100
53	100	100	100	100	100
54	100	100	100	100	100
55	100	100	100	100	100
56	100	100	100	100	100
57	100	100	100	100	100
58	100	100	100	100	100
59	100	100	100	100	100
60	100	100	100	100	100
61	100	100	100	100	100
62	100	100	100	100	100
63	100	100	100	100	100
64	100	100	100	100	100
65	100	100	100	100	100
66	100	100	100	100	100
67	100	100	100	1	

PAGE ____ OF ____

ॐ

CLIENT: DEP

W&P FILE #: 1079.01.02

CONTACT:

LABORATORY:

PROJECT: ROOFS / FACADE
LOCATION: 90 WASHINGTON ST.

ANALYSIS METHOD:	PCM	TEM	TEM

7400
circle one

TECHNICIAN: EDWIN B. ELLS JR

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRA- (lb./cc.)
01	IN DECON CLEAN RUN	3		3 3	0800 1600	480	1440	
02	BURCHASE ROOF ENTRANCE	3		3 3	0801 1601	480	1440	
03	WESTSIDE OF ROOF	3		3 3	0802 1602	480	1440	
04	SOUTHWEST OF ROOF	3		3 3	0803 1603	480	1440	
05	SOUTHWEST ROOF	3		3 3	0804 1604	480	1440	
06	SEALED FIELD BANK							
07	FIELD BLANK							
08	FIELD BLANK							

CONTRACTS:

SAMPLE BY: T. ELLIS

102-1-032

SIGNATURE: Edmund B. Elders III

RELEASED BY: DATE:

SIGNATURE:

RECEIVED BY: A. C. [Signature] DATE: 11/6/62

SIGNATURE: _____

5 - Final Clearance (inside)

7 - Personal

B - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

11/07/2002 18:11 FAX

006

**ATHENICA**
 ENVIRONMENTAL SERVICES INC.
 Tel. (718) 784-7490
 Fax. (718) 784-4085

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-11-035
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.013433
PROJECT: NYC DBP, 90 Washington Street
DATE OF REPORT: 11/06/02
DATE OF ANALYSIS: 11/06/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (m ²)	ANALYT. SENSITV. (struct./cm ³)	TOTAL ASBESTOS AIR CONC. (fibre/cm ³)	TOTAL ASBESTOS FILTER CONC. (fibre/cm ³)	AIR CONC. FOR STRUCT. 0.5S-5µm	AIR CONC. FOR STRUCT. ≥25.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-11-035-3876	By the decon	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA
02	T02-11-035-3877	Inside work area entrance	1440	4	0.0537	0.0050	0.0050	18.61	0.0050	<0.0050	Chrys.	NA
03	T02-11-035-3878	Inside work area south	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA
04	T02-11-035-3879	Inside work area east	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA
05	T02-11-035-3880	Inside work area west	1440	4	0.0537	0.0050	<0.0050	<18.61	NA	NA	NA	NA

ANALYST
 E. Storkri

LABORATORY DIRECTOR
 Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10953

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athena Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0877
Fax (212) 922-0830**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

Fax (212) 922-0830

24 hr + 1/8

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: NY DEP

W&P FILE #: 1079:05:02

LABORATORY: AT 142-NHCA

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	AHEBA	EPA LEVEL

TECHNICIAN: College Nurse

CUSTOMER: NY DEP
PROJECT: Roof Cleaning Remarks:
LOCATION: 90 Washington Street

CONTACT: Mr. Miller Noble

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	By the Decon	3		04 04	0830 1430	360	1440	
02	Inside work area Entrance	3		04 04	0832 1432	360	1440	
03	Inside work area South	3		04 04	0834 1434	360	1440	
04	Inside work area East	3		04 04	0836 1436	360	1440	
05	Inside work area West	3		04 04	0838 1438	360	1440	
06	Field Blank	1						
07	Field Blank	1						
08	Capped Blank	1						

COMMENTS:

SAMPLE BY: Celestina Jimenez DATE: 11/07/07

SIGNATURE: CDW. INF

RELEASED BY: COLostine Almaraz DATE: 11/25/02

SIGNATURE: Conny

RECEIVED BY: A. C. M. E. A. DATE: 11/1/00

SIGNATURE: _____

702-11-035

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION ASBESTOS INSPECTION REPORT

TOTAL FEET: 7600 0

Basis of Inspection:

FL	SF	LF
RO	2500	0

TRU/789MN02

ONLY TYPEWRITTEN
APPLICATIONS WILL BE
ACCEPTED

NOTE: ASBESTOS INSPECTION REPORT SHALL BE SUBMITTED
TO NYC DEP NOT LESS THAN ONE WEEK IN ADVANCE
OF START OF THE WORK (ABATEMENT ACTIVITIES)

FEE EXEMPT: Yes

1. \$0.00

11,809

START DATE: 10/28/2002 COMPLETION DATE: 11/13/2002

I. FACILITY

ADDRESS: 90 Washington Street BORO: MANHATTAN ZIP: _____
TYPE OFFACILITY: _____ BLOCK: _____ LOT: _____

II. BUILDING OWNER

NAME: N/A Zar Realty, Inc.
TEL. #: _____
ADDRESS: N/A N/A N/A N/A CITY: N/A STATE: N/A ZIP: 11368

IV. ASBESTOS ABATEMENT CONTRACTOR

NAME: TRIO ASBESTOS REMOVAL CORP
TEL. #: (718) 961-4100 FEDERAL EMPLOYER IDENTIFICATION #: PII
ADDRESS: 14-20 129TH STREET CITY: COLLEGE POINT STATE: NY ZIP: 11356

V. THIRD PARTY AIR MONITOR

NAME: WARREN & PANZER GROUP
TEL. #: _____
ADDRESS: 228 EAST 45TH STREET CITY: NEW YORK STATE: NY ZIP: 10017

VI. LABORATORY FOR SAMPLE ANALYSIS

NAME: WKP LABORATORIES C/O WARREN & PANZER

NYS ELAP #: 11251

ASBESTOS WORK SCHEDULE ☒ DAY ☒ EVENING ☐ NIGHT ☒ WEEKENDS ☒ WEEKDAYS

INSPECTOR NAME: R. Ramonohan SQUAD #: 1 BADGE #: A078

DATE OF INSPECTION: 10/28/02 - 11/05/02 TIME OF INSPECTION: From: 8 am AM ☒ PM ☐
To: 5 pm AM ☐ PM ☒

Contact at site: Jan Wolkowicz + 5 Handlers, Celestine Obikaw / W&P

Inspection disclosed that the following sections were complied with: (Check all that apply)		
☐ 1-51 - Notifications, Reports, Plan	☒ 1-71 - Air Sampling and Monitoring	☒ 1-91 - Worker Protection
☐ 1-101 - Materials and Equipment	☒ 1-116 - Work Place Preparation	☒ 1-117 - Worker Decontamination System
☐ 1-118 - Waste Decontamination System	☐ 1-126 - Engineering Controls	☐ 1-127 - Entry/Exit Procedures
☐ 1-129 - Maintenance of Barriers	☐ 1-138 - Encapsulation	☐ 1-139 - Enclosure
☐ 1-140 - Glovebag	☐ 1-141 - Tent	☒ 1-137 - ACM Disturbance, Removal, Handling
☐ 1-146 - Preliminary Clean-up	☐ 1-147 - Final Clean-up	
☐ Project not started _____ . Inspection		
revealed all ACM to be intact. New start date: _____		
☐ Project ongoing, expected completion date: _____		
☐ Project completed on or about: _____ . All surfaces, including abated surfaces are free of visible ACM and encapsulate		
☐ Follow up necessary on _____		
Samples taken: ☒ No ☐ Yes 1 _____ 2 _____ 3 _____		
4 _____ 5 _____ 6 _____ Photos taken: ☐ Yes ☒ No		
Additional comments: 10/28/02 MONDAY: Jan Wolkowicz + 7 Handlers constructed a decon unit at 27 th floor and began bagging the debris and pebbles on the 13 th floor setback. Air sampling was performed.		
10/29/02 TUESDAY: Jan Wolkowicz + 6 Handlers cleaning at the east wing of 13 th floor setback. Air sampling was performed.		
10/30/02 WEDNESDAY: Jan Wolkowicz + 6 Handlers, 13 th floor setback. Set back washing completed at 12:30 pm and bag out completed at the end of the day. Air sampling performed.		
10/31/02 THURSDAY: Ireneusz Womoczyl + 8 Handlers, began washing the gravel on bulkhead roof. Celestine Obikaw of Warren & Panzer performed air sampling.		

BORO 1 = MANHATTAN 2 = BRONX 3 = BROOKLYN 4 = QUEENS 5 = STATEN ISLAND
RESULT CODES 1 = VIOLATION ISSUED 2 = NO VIOLATION ISSUED 3 = NO ACCESS
4 = PROJECT NOT STARTED (NO NOV) 5 = PROJECT COMPLETED (NO NOV)

RESULT CODE

5

SUPERVISOR INITIALS

RE

NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION ASBESTOS INSPECTION REPORT

TOTAL FEET: 7600 0

Basis of Inspection:

FL	SF	LF
RO	7600	0

TRU1789MN02

FEE EXEMPT: Yes

1. \$0.00

ONLY TYPEWRITTEN
APPLICATIONS WILL BE
ACCEPTED

NOTE: ASBESTOS INSPECTION REPORT SHALL BE SUBMITTED
TO NYC DEP NOT LESS THAN ONE WEEK IN ADVANCE
OF START OF THE WORK (ABATEMENT ACTIVITIES)

START DATE: 11/1/2002 COMPLETION DATE: 11/1/2002

I. FACILITY

ADDRESS: 90 Washington Street BORO: MANHATTAN ZIP: _____
TYPE OFFACILITY: _____ BLOCK: _____ LOT: _____

II. BUILDING OWNER

NAME: N/A
TEL. #: _____
ADDRESS: N/A N/A N/A N/A CITY: N/A STATE: N/A ZIP: 11368

IV. ASBESTOS ABATEMENT CONTRACTOR

NAME: TRIO ASBESTOS REMOVAL CORP
TEL. #: (718) 961-4100 FEDERAL EMPLOYER IDENTIFICATION #: PII
ADDRESS: 14-20 129TH STREET CITY: COLLEGE POINT STATE: NY ZIP: 11356

V. THIRD PARTY AIR MONITOR

NAME: WARREN & PANZER GROUP
TEL. #: _____
ADDRESS: 228 EAST 45TH STREET CITY: NEW YORK STATE: NY ZIP: 10017

VI. LABORATORY FOR SAMPLE ANALYSIS

NAME: WKP LABORATORIES C/O WARREN & PANZER
NYS ELAP #: 11251

ASBESTOS WORK SCHEDULE ☒ DAY ☒ EVENING ☐ NIGHT ☒ WEEKENDS ☒ WEEKDAYS

INSPECTOR NAME: _____ SQUAD #: _____ BADGE #: _____

DATE OF INSPECTION: _____ TIME OF INSPECTION: From: _____ AM ☐ PM ☐To: _____ AM ☐ PM ☐

Contact at site: _____

Inspection disclosed that the following sections were complied with: (Check all that apply)

- | | | |
|---|---|---|
| ☐ 1-51 - Notifications, Reports, Plan | ☐ 1-71 - Air Sampling and Monitoring | ☐ 1-91 - Worker Protection |
| ☐ 1-101 - Materials and Equipment | ☐ 1-116 - Work Place Preparation | ☐ 1-117 - Worker Decontamination System |
| ☐ 1-118 - Waste Decontamination System | ☐ 1-126 - Engineering Controls | ☐ 1-127 - Entry/Exit Procedures |
| ☐ 1-129 - Maintenance of Barriers | ☐ 1-138 - Encapsulation | ☐ 1-139 - Enclosure |
| ☐ 1-140 - Glovebag | ☐ 1-141 - Tent | ☐ 1-137 - ACM Disturbance, Removal, Handling |
| ☐ 1-146 - Preliminary Clean-up | ☐ 1-147 - Final Clean-up | |
| ☐ Project not started _____ . Inspection | | |

revealed all ACM to be intact. New start date: _____

☐ Project ongoing, expected completion date: _____☐ Project completed on or about: _____ . All surfaces, including abated surfaces are free of visible ACM and encapsulate☐ Follow up necessary on _____Samples taken: ☐ No ☐ Yes 1 _____ 2 _____ 3 _____4 _____ 5 _____ 6 _____ Photos taken: ☐ Yes ☐ No

Additional comments: 11/01/02 Friday: Ireneusz Womoczyl + 8 Handlers.

Started washing the roof gravel on the main roof. Celestine obika performed air sampling for Warren & Panzer.

11/02/02 Saturday: Ireneusz and crew continue the gravel washing on main roof. Air sampling was conducted by Celestine.

11/03/02 SUNDAY: Ireneusz & crew continued the roof gravel washing. Air sampling was performed by Celestine obika & Edwin Ellis.

11/04/02 MONDAY: Ireneusz & crew of 7 handlers continued gravel washing on roof.

11/05/02 TUESDAY: Ireneusz & crew gravel washing completed. Bags of waste removed completed.

BORO 1 = MANHATTAN 2 = BRONX 3 = BROOKLYN 4 = QUEENS 5 = STATEN ISLAND

RESULT CODES 1 = VIOLATION ISSUED 2 = NO VIOLATION ISSUED 3 = NO ACCESS

4 = PROJECT NOT STARTED (NO NOV) 5 = PROJECT COMPLETED (NO NOV)

RESULT CODE

5

SUPERVISOR INITIALS

fe