

OCT-15-2002 12:32

BANHM LABORATORY UNIT

P.02/07

**ATHENICA**

ENVIRONMENTAL SERVICES INC.
Tel. (718) 784-7490
Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-10-060
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.013838

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

PROJECT: NYCDER, 12 Plan Street
DATE OF REPORT: 10/11/02
DATE OF ANALYSIS: 10/11/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	C.O.D. ANAL. YZ88	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (pf/cc-ft ³)	TOTAL ASBESTOS AIR CONC. (pf/cc-ft ³)	TOTAL ASBESTOS FILTER CONC. (pf/cc-ft ³)	AIR CONC. FOR STRUCT. 0.555-5pm	AIR CONC. FOR STRUCT. 0.555-5pm	ASBEST. TYPE CHRYS.	ASBEST. TYPE SPECIFY
ID 01	T02-10-060-2983	IWA 1 st right side of WA	1530	4	0.0554	0.0045	<0.0045	<18.07	NA	NA	NA	NA
ID 02	T02-10-060-2984	IWA 2 nd right side of WA	1530	4	0.0554	0.0045	<0.0045	<18.07	NA	NA	NA	NA
ID 03	T02-10-060-2985	IWA 3 rd right side of WA	1530	4	0.0554	0.0045	<0.0045	<18.07	NA	NA	NA	NA
ID 04	T02-10-060-2986	Exit to the roof	1530	4	0.0554	0.0045	<0.0045	<18.07	NA	NA	NA	NA
ID 05	T02-10-060-2987	IWA left side of WA	1530	4	0.0554	0.0045	<0.0045	<18.07	NA	NA	NA	NA

ANALYST
E. Sioukri

LABORATORY DIRECTOR
Spiro Dragaris

LABORATORY CERTIFICATION NUMBERS: NY LAF 101956, 8-LAF 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NY LAF or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

OCT-15-2002 11:31

TECHNICIAN: ZD R15 ID ONLY

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./co.)
				START	STOP	ON	OFF			
ID01	IWA 1 st RIGHT SIDE OF WA	03		3		0905	1735	510	1530	
ID02	IWA 2 nd RIGHT SIDE OF WA	03		3		0906	1736	510	1530	
ID03	IWA 3 rd RIGHT SIDE OF WA	03		3		0907	1737	510	1530	
ID04	ENTR TO THE ROOF.	03		3		0908	1738	510	1530	
ID05	IWA LEFT SIDE OF WA.	03		3		0910	1740	510	1530	
ID06	Field blank	01				N/A				
ID07	Field blank	01				N/A				
ID08	Sealed blank	01				N/A				

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

FREE REVERSE SIDE FOR ANALYSIS INFORMATION