

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Received: 6/28/02

7:00:00 PM

ATC Group #: 8324

Analysis Date: 6/29/02

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC- DEP, W&P# 1079.01.02

104 Reade Street, Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8324 -1	1470.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
02 8324 -2	1470.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
03 8324 -3	1470.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
04 8324 -4	1470.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047
05 8324 -5	1470.00	0.0562	0	None Detected	0	0	0.0047	<17.79	<0.0047

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

26

Page 1 of 1



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280

FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8324

Date: Saturday, June 29, 2002

Client Project: NYC- DEP. W&P# 1079.01.02
104 Reade Street, Roof

Time: 12:51:53 PM

Comments:

Number of Pages: 3
(including cover page)

25