



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8363

Date: Monday, July 01, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
107 Reade Street

Time: 2:46:14 PM

Number of Pages: 3

Comments:

(including cover page)

27



104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

107 Reade Street

Received: 7/1/02

8:00:00 AM

ATC Group #: 8363

Analysis Date: 7/1/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
01 8363 -1	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	
02 8363 -2	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	
03 8363 -3	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	
04 8363 -4	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	
05 8363 -5	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

28

Page 1 of 1

WARREN & PANZER ENGINEERS, P. C.

AIR-MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

W&P FILE #: 1079-01-02

CONTACT:

CLIENT: NYC DEP

PROJECT: 107 DEADE ST

LOCATION: **GRADE:**

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM TEM

TEM TEM

circle one
7400 AHERA EPA LEVEL II

TECHNICIAN
R. FERNANDEZ

8363

[illegible]

COMMENTS:

SAMPLE BY: R. F. [Signature] DATE: 6-20-72

DATE: 6-20-12

SIGNATURE: _____

RELEASED BY: [Signature] DATE:

SIGNATURE:

RECEIVED BY: *MAC* DATE: 7/6/02

SIGNATURE: 

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

107 Reade Street

Received: 7/1/02

8:00:00 AM

ATC Group #: 8363

Analysis Date: 7/1/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8363 -1	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
02 8363 -2	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
03 8363 -3	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
04 8363 -4	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
05 8363 -5	1360.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-D, NY State ELAP #10879

28

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

PROJECT: 107 READE ST
LOCATION: READE

8363

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
1	100	100	100	100	100
2	100	100	100	100	100
3	100	100	100	100	100
4	100	100	100	100	100
5	100	100	100	100	100
6	100	100	100	100	100
7	100	100	100	100	100
8	100	100	100	100	100
9	100	100	100	100	100
10	100	100	100	100	100
11	100	100	100	100	100
12	100	100	100	100	100
13	100	100	100	100	100
14	100	100	100	100	100
15	100	100	100	100	100
16	100	100	100	100	100
17	100	100	100	100	100
18	100	100	100	100	100
19	100	100	100	100	100
20	100	100	100	100	100
21	100	100	100	100	100
22	100	100	100	100	100
23	100	100	100	100	100
24	100	100	100	100	100
25	100	100	100	100	100
26	100	100	100	100	100
27	100	100	100	100	100
28	100	100	100	100	100
29	100	100	100	100	100
30	100	100	100	100	100
31	100	100	100	100	100
32	100	100	100	100	100
33	100	100	100	100	100
34	100	100	100	100	100
35	100	100	100	100	100
36	100	100	100	100	100
37	100	100	100	100	100
38	100	100	100	100	100
39	100	100	100	100	100
40	100	100	100	100	100
41	100	100	100	100	100
42	100	100	100	100	100
43	100	100	100	100	100
44	100	100	100	100	100
45	100	100	100	100	100
46	100	100	100	100	100
47	100	100	100	100	100
48	100	100	100	100	100
49	100	100	100	100	100
50	100	100	100	100	100
51	100	100	100	100	100
52	100	100	100	100	100
53	100	100	100	100	100
54	100	100	100	100	100
55	100	100	100	100	100
56	100	100	100	100	100
57	100	100	100	100	100
58	100	100	100	100	100
59	100	100	100	100	100
60	100	100	100	100	100
61	100	100	100	100	100
62	100	100	100	100	100
63	100	100	100	100	100
64	100	100	100	100	100
65	100	100	100	100	100
66	100	100	100	100	100
67	100	100	100	1	

W&P FILE #: 1079-01-02

LABORATORY: ATC

ANALYSIS METHOD:

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: R. FERNANDEZ

CONTACT:

TEM

HERA EPA LEVEL II

TECHNICIAN: R. FERNANDEZ

[illegible]

COMMENTS:

SAMPLE BY: R. PERDUE

DATE: 6-30-02

SIGNATURE

RELEASED BY:

DATE:

SIGNATURE:

RECEIVED BY.

DATE: 7/21/02

SIGNATURE:

1

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8363

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
107 Reade Street

Date: Monday, July 01, 2002

Time: 2:46:14 PM

Number of Pages: 3
(including cover page)

Comments:

27