

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/1/02 3:00:00 PM
 ATC Group #: 8369
 Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077
 Project: NYC-DEP W & P File #: 1079.01.02
 109 Reade Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8369 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
02 8369 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
03 8369 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
04 8369 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
05 8369 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report releases only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10876

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1
P.O.

8369

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1019-01-02

LABORATORY: ATC

CONTACT:

CLIENT: NYC DEP

PROJECT: 109 READE ST

LOCATION: FACADE

ANALYSIS METHOD: PCM
circle one 7400 TEM
AHERA EPA LEVEL II

TECHNICIAN: R. TROTT

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)
01	(1) SIDE BARREL	3		10.0	10.0	1310	1510	130	1300	
02	(1) SIDE OF FACADE	3		10.0	10.0	1312	1512	130	1300	
03	MIDDLE OF BARREL	3		10.0	10.0	1315	1515	130	1300	
04	(2) SIDE WINDY SIDE	3		10.0	10.0	1317	1517	130	1300	
05	(2) SIDE BARREL	3		10.0	10.0	1320	1520	130	1300	
06	FB	1				NA	NA			
07	FB	1				NA	NA			

COMMENTS:

SAMPLE BY: <u>R. TROTT</u>	DATE: <u>6/3/02</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>[Signature]</u>	DATE: <u>7/1/02</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>ATC</u>	DATE: <u>7/1/02</u>
SIGNATURE: <u>[Signature]</u>	DATE: <u>15:00</u>

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Monday, July 01, 2002

Time: 11:19:29 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8369

Client Project: NYC-DEP W & P File #: 1079.01.02
109 Reade Street

Number of Pages:

3
(including cover page)

10

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/1/02

3:00:00 PM

ATC Group #: 8369

Analysis Date: 7/1/02

Project: NYC-DEP W & P File #: 1079.01.02

109 Reade Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 8369 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
02 8369 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
03 8369 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
04 8369 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
05 8369 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879

PAGE 1 OF 1

CLIENT: NYC DEP
PROJECT: 109 READE ST
LOCATION: TROOP

W&P FILE #: 1079-01-62
LABORATORY: ATC
ANALYSIS METHOD: PGM TEM .TEM
c/cb one 7400 AHERA EPA LEVEL III
TECHNICIAN: R. TROTTENBERG

CONTACT:

2.

[illegible]

COMMENTS:

SAMPLE BY: Ramiro Texidor DATE: 6:30 42
 SIGNATURE: _____
 RELEASED BY: _____ DATE: _____
 SIGNATURE: _____
 RECEIVED BY: ARC DATE: 7/1/02
 SIGNATURE: [Signature] 15:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Monday, July 01, 2002

Time: 11:19:29 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8369

Client Project: NYC-DEP W & P File #: 1079.01.02
109 Reade Street

Number of Pages: 3
(including cover page)

10