

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
110 Rcade Street

Received: 7/13/02

8:30:00 PM

ATC Group #: 8485

Analysis Date: 7/14/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
001A 8485 -1	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
002A 8485 -2	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
003A 8485 -3	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
004A 8485 -4	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042
005A 8485 -5	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-Q, NY State ELAP #10879

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

8485

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: NYC DEP
PROJECT: Facade Clean
LOCATION: 110 Reade St

W&P FILE #: 1079-01-02
LABORATORY: ATC
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II
TECHNICIAN: N. Wells

CONTACT: Mike Miller
LLW#: _____
SCA JOB#: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
001A	Entrance area by steps	3		10 10	15:15 17:30	135	1350	
002A	Adj to cellar door	3		10 10	15:16 17:31	135	1350	
003A	Adj to bldg in street	3		10 10	15:17 17:32	135	1350	
004A	Next to ramp to bldg	3		10 10	15:18 17:33	135	1350	
005A	adj to ramp in street	3		10 10	15:19 17:34	135	1350	
006A	Field	1		10 10	15:15 17:30			
007	Field	1		10 10	15:16 17:31			
008	Sealed	1		10 10	15:17 17:32			

COMMENTS:

SAMPLE BY: N. Wells DATE: 7/13/02
SIGNATURE: N. Wells
RELEASED BY: _____ DATE: _____
SIGNATURE: _____
RECEIVED BY: ATC DATE: 07/13/02
SIGNATURE: M. Gray 19:15

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8485

Date: Thursday, July 14, 1983

Client Project: NYC DEP. W&P# 1079.01.02
110 Rade Street

Time: 9:43:49 AM

Number of Pages: 3

(including cover page)

Comments: