

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

111 Read Street

Received: 7/11/02

3:45:00 PM

ATC Group #: 8449

Analysis Date: 7/11/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8449 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
02 8449 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
03 8449 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
04 8449 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
05 8449 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

**2220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.

AIR-MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
P.O. _____					

W&P FILE #: 1079-01-62

CONTACT:

CLIENT NYC DEP

PROJECT III READ ST

LOCATION: Roof-

LABORATORY: ATC

ANALYSIS METHOD:	PCM	TEM	TEM
------------------	-----	-----	-----

THE TEAM

circle one
7400 ANHRA EPA LEVEL II

TECHNICIAN: R. FORD

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (fib./cc.)
01	ENDACE TO ROOF	3		10.0 10.0	1501 1541	130	1700	
02	ENDACE	3		10.0 10.0	1542 1572			
03	IN A HOIST	3		10.0 10.0	1574 1574			
04	IN A ROOF	3		10.0 10.0	1576 1576			
05	IN A MIDDLE	3		10.0 10.0	1578 1588	150	1360	
06	FB	1			NA			
07	FB	1			NA			

COMMENTS:

SAMPLE BY: R TAYLOR
SIGNATURE: [Signature]
RELEASED BY:
SIGNATURE:
RECEIVED BY: ATC
SIGNATURE: [Signature]

DATE: 7-11
DATE: 7/11/02
15:45

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8449

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
111 Read Street

Date: Thursday, July 11, 2002

Time: 11:44:09 PM

Comments:

Number of Pages: 3
(including cover page)