

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

60 Pine Street, NYC

Received: 7/12/02

5:10:00 PM

ATC Group #: 8469

Analysis Date: 7/13/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
DE001 8469 -1	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE002 8469 -2	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE003 8469 -3	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE004 8469 -4	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE005 8469 -5	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10878

WARREN & PANZER ENGINEERS, P. C.
New York, NY 10017
(212) 922-0077
Fax (212) 922-0580

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

PROJECT: 60 PINE ST NYC

LABORATORY: A.T.C.

CONTACT: MIKE NOLAN

LOCATION: Roof

ANALYSIS METHOD: PCM 7400

LLW#:

circle one

TECHNICIAN: Dipo Etema

SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb/sec.)
DE001	OWA Exit to roof	3		3	3	0830	1615	465	1395	
DE002	by Decon	3		3	3	0831	1616	465	1395	
DE003	OWA right of WA	3		3	3	0832	1617	465	1395	
DE004	✓ left ✓	3		3	3	0833	1618	465	1395	
DE005	OWA middle ✓	3		3	3	0835	1620	465	1395	
DE006	field Blank	1		0	0	—	—	0	0	
DE007	✓	1		0	0	—	—	0	0	
DE008	Sealed Blank	1		0	0	—	—	0	0	

COMMENTS:

SAMPLE BY: Dipo Etema DATE: 7/12/02

SIGNATURE: *[Signature]*

RELEASED BY: Dipo Etema DATE: 7/12/02

SIGNATURE: *[Signature]*

RECEIVED BY: AT Lab / D. Kozm / DATE: 07/12/02

SIGNATURE: *[Signature]* 17.10

SAMPLE TYPE CODES			
1 - Blank	2 - Pre-Abatement	5 - Final Clearance (inside)	
3 - During Abatement	4 - During Glove Bag Removal	6 - Final Clearance (outside)	
		7 - Personal	
		8 - Background	

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8469

Date: Wednesday, July 13, 1988

Client Project: NYC DEP. W&P# 1079.01.02
60 Pine Street, NYC

Time: 1:47:36 PM

Comments:

Number of Pages: 3
(including cover page)