

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 43rd Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

60 Pinest

Received: 7/13/02

8:00:00 PM

ATC Group #: 8482

Analysis Date: 7/13/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
1 8482 -1	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
2 8482 -2	1800.00	0.0450	0	CHRYSTOLE	1	0.0048	22.24	0.0048
3 8482 -3	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
4 8482 -4	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
5 8482 -5	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-C, NY State ELAP #10879

2848

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____
P.O. _____

CLIENT: NYC DEP
PROJECT: 6th FIVES
LOCATION: FACAD

W&P FILE #: 107-01-02
LABORATORY: A I C
ANALYSIS METHOD: PCM
7400
circle one
TEM
AHERA
EPA LEVEL

CONTACT: MAC
LIW#:
SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb/cf)
1	D.W.A. - 1 E. S. F.	3	1	5 5	1 00 0 1 00	360	1800	
2	D.W.A. - west	3	2	5 5	1 00 1 00	360	1800	
3	D.W.A. south	3	3	5 5	1 00 2 1 00	360	1800	
4	D.W.A. north	3	4	5 5	1 00 3 1 00	360	1800	
5	D.W.A. center	3	5	5 5	1 00 4 1 00	360	1800	
6	field blank	1						
7	field blank	1						
8	field blank	1						

COMMENTS:

SAMPLE BY: DAVID GREENBERG DATE: 7/17/67
SIGNATURE: DAVID GREENBERG
RELEASED BY: DAVID GREENBERG DATE: 7/17/67
SIGNATURE: DAVID GREENBERG
RECEIVED BY: ATC DATE: 07/19/67
SIGNATURE: H. Gray

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

OFF BEVERAGE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Fedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8482

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
60 Pinest

Date: Wednesday, July 13, 1988

Time: 10:35:24 PM

Comments:

Number of Pages: 3
(including cover page)