

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

60 Pine Street, New York, NY

Received: 7/13/02

8:30:00 PM

ATC Group #: 8483

Analysis Date: 7/14/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
DE001 8483 -1	1560.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044
DE002 8483 -2	1560.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044
DE003 8483 -3	1560.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044
DE004 8483 -4	1560.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044
DE005 8483 -5	1560.00	0.0562	0	None Detected	0	0	0.0044	<17.79	<0.0044

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-5, NY State ELAP #10878

2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-6630

PAGE 1 OF 1

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8483

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

0039-726 (217) x83
1100-726 (217)

W&P FILE #: 679-01-02

CLIENT: W.C. DEF

PROJECT: ~~GO~~ PINE ST NYC

LOCATION: Courtyard

LABORATORY:

ANALYSIS METHOD: PCM

circle one,

TECHNICIAN: Δ PD EDEMO

CONTACT: MIKE VOLTA

— 11 —

SCA-1084:

SAMPLE NUMBER	SAMPLE DESCRIPTION LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
DE001	DWA Effluent to roof	3		4 4	1000 1630	390	1560	
DE002	Ry Decan	3		4 4	1001 1631	390	1560	
DE003	WA right of WA	3		4 4	1002 1632	390	1560	
DE004	left - ✓	3		4 4	1003 1633	390	1560	
DE005	WA middle - ✓	3		4 4	1005 1635	390	1560	
DE006	field Blank	1		0 0	0 0	0	0	
DE007	✓	1		0 0	0 0	0	0	
DE008	Scaled Blank	1		0 0	0 0	0	0	

COMMENTS:

SAMPLE BY:	DPO ELEMND	DATE: 7/13/02
SIGNATURE:	<i>[Signature]</i>	
RELEASED BY:	DPO ELEMND	DATE: 7/13/02
SIGNATURE:	<i>[Signature]</i>	
RECEIVED BY:	A.T.C.	DATE: 07/13/02
SIGNATURE:	<i>H. Graf</i>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8483

Date: Thursday, July 14, 1988

Client Project: NYC DEP. W&P# 1079.01.02
60 Pine Street, New York, NY

Time: 9:00:33 AM

Number of Pages: 3

(including cover page)

Comments: