

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

60 Pine Street

Received: 7/15/02

7:00:00 AM

ATC Group #: 8501

Analysis Date: 7/15/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
1 8501 -1	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
2 8501 -2	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
3 8501 -3	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045
4 8501 -4	1530.00	0.0562	0	CHRYSTOLE	1	0	0.0045	17.79	0.0045
5 8501 -5	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC DEP

PROJECT:

LOCATION: CO DIST.

1501

W&P FILE #: 107-01-02

LABORATORY:

ANALYSIS METHOD:

circle one

TECHNICIAN:

CONTACT: MMC

#A17

SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME (liters)	CONCENTRATION (lib./cc.)
				START	STOP	ON	OFF			
1	OWA east	3		3	3	1000	1830	510	1530	
2	OWA west	3		3	3	1000	1830	510	1530	
3	OWA north	3		3	3	1000	1830	510	1530	
4	OWA south	3		3	3	1000	1830	510	1530	
5	OWA center	3		3	3	1000	1830	510	1530	
6	field center	1								
7	field center	1								
8	field center	1								

COMMENTS:

SAMPLE BY: DAVID GREENBERG DATE: 7/14/02

SIGNATURE: Daniel

RELEASED BY: DAVID T. SUTHERLY DATE: 7/14/85

SIGNATURE: D. J. [Signature]

RECEIVED BY: AJC DATE: 7/15/02

SIGNATURE: LD DATE: 7/19/02

DATE: 7/14/02

334

DATE: 7/14/62

DATE: 11/1/20

DATE: 7/15/02

725

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8501

Date: Monday, July 15, 2002

Client Project: NYC DEP. W&P# 1079.01.02
60 Pine Street

Time: 3:14:18 PM

Comments:

Number of Pages: 3
(including cover page)

10