

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/11/02

5:23:00 PM

ATC Group #: 8451

Analysis Date: 7/12/02

Project: NYC DEP, W&P# 1079.01.02

60 Pine Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
DE001 8451 -1	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
DE002 8451 -2	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
DE003 8451 -3	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
DE004 8451 -4	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
DE005 8451 -5	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101167-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

Fax (212) 922-8830

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

 P_2O_5

CLIENT: N.Y.C. DEP

W&P FILE #: 1079-01-02

CLIENT: NYC DEP
PROJECT: 60 PINE ST NYC
LOCATION: ROOF

CONTACT: MIKE MOLAN

PROJECT:

100 PINE ST NYC

ANALYSIS METHOD: PCM TEM TEM

新門

LOCATION:

ALERT (MEL)

SCAJOB#:

TECHNICIAN: D120 ~~EDMO~~

[illegible]

COMMENTS:

SAMPLE BY:	Dipo Etemo	DATE:	7/11/02
SIGNATURE:	Dipo E		
RELEASED BY:	Dipo Etemo	DATE:	7/11/02
SIGNATURE:	Dipo		
RECEIVED BY:	McC Lab / Schoof	DATE:	07/11/02
SIGNATURE:	S. McC		17.23

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8451

Date: Fridav. July 12. 2002

Client Project: NYC DEP. W&P# 1079.01.02
60Pins Street, NewYork, NY

Time: 10:00:33 AM

Comments:

Number of Pages: 3
(including cover page)