

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/12/02

5:10:00 PM

ATC Group #: 8469

Analysis Date: 7/13/88

Project: NYC DEP, W&P# 1079.01.02
60 Pine Street, NYC

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
DE001 8469 -1	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE002 8469 -2	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE003 8469 -3	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE004 8469 -4	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	
DE005 8469 -5	1395.00	0.0674	0	None Detected	0	0	0.0041	<14.83	<0.0041	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

NEW YORK, NY 10017
 (212) 922-0077
 Fax (212) 922-0690

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: NYC DEP
 PROJECT: 60 PINE ST NYC
 LOCATION: Roof

W&P FILE #: 1079-01-02
 LABORATORY: A.T.C.
 ANALYSIS METHOD: PCM TEM TEM
 circle one 7400 AHERA EPA LEVEL II
 TECHNICIAN: Dipo ELEMA

CONTACT: MIKE NOLAN
 LLW#: _____
 SCA JOB#: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
DE001	OWA EXIT to roof	3		3 3	0830 1615	465	1395	
DE002	By Decon	3		3 3	0831 1616	465	1395	
DE003	OWA right of OWA	3		3 3	0832 1617	465	1395	
DE004	✓ left ✓	3		3 3	0833 1618	465	1395	
DE005	OWA middle -	3		3 3	0835 1620	465	1395	
DE006	Field Blank	1		0 0	— —	0	0	
DE007	✓	1		0 0	— —	0	0	
DE008	Sealed Blank	1		0 0	— —	0	0	
						0	0	

COMMENTS:

#8463 8469
 WP

SAMPLE BY: Dipo ELEMA DATE: 7/12/02
 SIGNATURE: *Dipo*
 RELEASED BY: Dipo ELEMA DATE: 7/12/02
 SIGNATURE: *Dipo*
 RECEIVED BY: ATC Lab 18 Kosovl DATE: 07/12/02
 SIGNATURE: *Atk* 17.10

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8469

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
60 Pine Street, NYC

Date: Wednesday, July 13, 1988

Time: 1:47:36 PM

Comments:

Number of Pages: 3
(including cover page)