

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/15/02

7:00:00 AM

ATC Group #: 8500

Analysis Date: 7/15/02

Project: NYC DEP, W&P# 1079.01.02

60 Pine Street, Courtyard

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
DE 01 8500 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
DE 02 8500 -2	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
DE 03 8500 -3	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
DE 04 8500 -4	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
DE 05 8500 -5	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048

8

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

W&P FILE #: 1079-01-02

CLIENT: NYC DEP

PROJECT: 60 Pine St

LOCATION: Courtyard

LABORATORY: A.T.C.

ANALYSIS METHOD: PCM

TECHNICIAN: Dipo

CONTACT: Mike

LLW#:

SCA JOB#:

TECHNICIAN: Dipo

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb/cc)
DE01	OWA Exit to Roof	3		04 04	0900 1500	360	1440	
DE02	By DEcon	3		04 04	0901 1501	360	1440	
DE03	INA right of WA	3		04 04	0902 1502	360	1440	
DE04	- left -	3		04 04	0903 1503	360	1440	
DE05	INA Center -	3		04 04	0905 1505	360	1440	
DE06	field Blank	1		- -	- -	-	-	
DE07	-	1		- -	- -	-	-	
DE08	Sealed blank	1		- -	- -	-	-	

COMMENTS:

SAMPLE BY: Dipo Glens DATE: 7/14/02

SIGNATURE: Dipo

RELEASED BY: DAVID GLENESIC DATE: 7/14/02

SIGNATURE: Dipo

RECEIVED BY: ATC DATE: 7/15/02

SIGNATURE: JD

SAMPLE TYPE CODES			
1 - Blank	2 - Pre-Abatement	3 - During Abatement	4 - During Glove Bag Removal
5 - Final Clearance (inside)	6 - Final Clearance (outside)	7 - Personal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8500

Date: Monday, July 15, 2002

Client Project: NYC DEP. W&P# 1079.01.02
60 Pine Street Courtyard

Time: 3:12:47 PM

Comments:

Number of Pages: 3
(including cover page)

7