

Asbestos Inspection Report

Premise No. 205 PEARL STREET					Inspection Date: AS NOTED	
Floor ROOF & FACADE	Zip 10038	Borough 1	Block 68	Lot 7501	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type MIXED USE		Basis of Inspection WTC Survey		Photos Taken (Yes/No)
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: AS NOTED		
TUESDAY SEPTEMBER 10 2002 (0800AM - 0600 PM)						
THE CLEAN UP OF THE ROOF AREA OF THE PREMISE BEGINS TODAY, THE ROOF AREA OF THE ADJACENT BUILDING, 211 PEARL STREET, OCCURS SIMULTANEOUSLY (ROOFS ARE CONNECTED). FOR THE PURPOSES OF AIR SAMPLING THE ROOF AREAS OF THESE TWO BUILDINGS WILL BE TREATED AS ONE WORK AREA. A REMOTE DECONTAMINATION UNIT IS ERECTED ON THE ROOF OF THE PREMISE. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP PROJECT WAS PERFORMED BY FAYED ELGENDI (CERTIFICATE # AH-0111631 EXP 03/03). AIR SAMPLES ARE SET UP ON THE ROOF OF THE ADJACENT BUILDING 101 HAIDEN LANE.						
WEDNESDAY SEPTEMBER 11 2002						
NO WORK ACTIVITIES ARE SCHEDULED TODAY.						
THURSDAY SEPTEMBER 12 2002						
THE CLEAN UP OF THE ROOF WORK AREA IS COMPLETED. CLEAN UP ACTIVITIES BEGIN ON THE REAR (WEST) FACADE OF THE PREMISE. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP PROJECT WAS PERFORMED BY JOHN BOYD (CERTIFICATE # AH 90-05530 EXP 01/03).						
FRIDAY SEPTEMBER 13 2002						
THE CLEAN UP OF THE WEST (REAR) FACADE IS COMPLETED. CLEAN UP ACTIVITIES BEGIN IN THE SET BACK WORK AREA. AIR SAMPLING IS PERFORMED BY JOHN BOYD. FOR THE PURPOSES OF AIR MONITORING THE SETBACK WORK AREAS OF 205, 211, 213, AND 215 PEARL STREET ARE TREATED AS ONE WORK AREA. THE CLEAN UP ACTIVITIES AT THESE FOUR PREMISES OCCURS SIMULTANEOUSLY.						

Asbestos Inspection Report

Premise No. 205 PEARL STREET	Inspection Date: AS NOTED
Inspector Dennis Antzoulatos	Page <u>2</u> of <u>2</u>

SATURDAY SEPTEMBER 14 2002

THE CLEAN UP OF THE SETBACK WORK AREA IS COMPLETED. AIR SAMPLING WAS PERFORMED BY JOHN BOYD. AT THE COMPLETION OF THE CLEAN UP ACTIVITIES A VISUAL INSPECTION OF THE CLEANED WORK AREAS WAS CONDUCTED BY JOHN BOYD OF WARREN & PANZER. NO VISIBLE WTC DEBRIS WAS OBSERVED.

SUNDAY SEPTEMBER 15 2002

THE CLEAN UP OF THE EAST FACADE (PEARL ST) WAS CONDUCTED TODAY. THE FACADE CLEAN UP INVOLVED THE HEPA VACUUMING AND WET WIPING OF WINDOW SURFACES. A DECON TRUCK WAS UTILIZED. NO PLASTIC DYKE WAS CONSTRUCTED (NO WATER RUN OFF). AIR MONITORING FOR THIS PORTION OF THE CLEAN UP PROJECT WAS PERFORMED BY OCHOCHO ERHABOR (CERTIFICATE # AH 00-16198 EXP 12/02) OF WARREN & PANZER. UPON COMPLETION OF THE CLEAN UP ACTIVITIES I CONDUCTED A VISUAL OF THE CLEANED FACADE SURFACES AND I OBSERVED NO VISIBLE WTC DEBRIS. A BOOM TRUCK WAS USED TO ACCESS THE FACADE SURFACES. THE CLEAN UP PROJECT AT THIS PREMISE IS NOW COMPLETE.