

09/14/2002 00:41 FAX 716 784 4085

004

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (716) 784-7988
Fax. (716) 784-4085

CLIENT: Warren & Penzer Engineers, P.C.

LABORATORY ID #: T02-09-041

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.I.

AVERAGE G.O. AREA (mm²): 0.013771

PROJECT: NYC DEP, 211 Pearl Street

DATE OF REPORT: 09/13/02

DATE OF ANALYSIS: 09/13/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (microg./cm ³)	TOTAL ASBESTOS AIR CONC. (microg./cm ³)	TOTAL ASBESTOS FILTER CONC. (microg./mm ²)	AIR CONC. FOR STRUCT. 0.45<5µm	AIR CONC. FOR STRUCT. 5<10µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
JB9-01	T02-09-041-2274	By decon	1800	4	0.0551	0.0039	<0.0039	<18.15	NA	NA	NA	NA
JB9-02	T02-09-041-2275	On roof of 205 Pearl St. right	1800	4	0.0551	0.0039	<0.0039	<18.15	NA	NA	NA	NA
JB9-03	T02-09-041-2276	On roof of 205 Pearl St. right middle	1800	4	0.0551	0.0039	0.0039	18.15	0.0039	<0.0039	Chrys.	NA
JB9-04	T02-09-041-2277	On roof of 205 Pearl St. left middle	1800	4	0.0551	0.0039	<0.0039	<18.15	NA	NA	NA	NA
JB9-05	T02-09-041-2278	On roof of 205 Pearl St. left	1800	4	0.0551	0.0039	<0.0039	<18.15	NA	NA	NA	NA

ANALYST
B. SioulonLABORATORY DIRECTOR
Spito Desgaria

LABORATORY CERTIFICATION NUMBERS: NVLAP 181049 PJ AP 18002

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassette will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

222R East 45th Street
New York, NY 10017
(212) 922-9077
Fax (212) 922-9630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

Q. A.

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate +/a

CLIENT: W-1000

W&P FILE #: 1374. 01. 02

LABORATORY:

PROJECT: 211 Per 5 f (213-215)

LOCATION: 507 Buck 4975

ANALYSIS METHOD:	PCM	TEM	TEM

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: John. B 0111

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
J09 01	by D.C. 9L	3		3	0900 1900	600	1800	
J09 02	ON coast 205 Dead skiffish	3		3	0902 1902	↑	↑	
J09 03	" " " " 15.5m	3		3	0904 1904	↓	↓	
J09 04	" " " " 10.5m middle	3		3	0906 1906	↓	↓	
J09 05	" " " " 10.5m	3		3	0908 1908	600	1800	
J09 06	Field Blank	1		—	0 0	0	0	
J09 07	" " "	1		—	0 0	0	0	
J09 08	Sealed Blank	1		—	0 0	0	0	

COMMENTS:

140-60-201

SAMPLE BY: Jaha, 1394d. DATE: 6-12-04

SIGNATURE: *Don B. Co*

RELEASED BY: Jaha
Baird
DATE: 9-12-02

SIGNATURE: *[Signature]*

RECEIVED BY ACAT/KAL DATE: 9/13/07

SIGNATURE _____

SAMPLE TYPE CODES

Blank

2 - PIR-Ataítem!

3 - During Abatement

4 - During Glove Bag Removal

5 - Final Clearance (inside)

B. Final Clearance (outside)

7. Personal

A - Background

SEE REVERSE SIDE FOR ANNUAL VISA RENEWAL