


ATHENICA

ENVIRONMENTAL SERVICES INC.

 Tel. (718) 784-7490
 Fax. (718) 784-4885

 CLIENT: Warren & Pauset Engineers, P.C.
 LABORATORY ID #: T02-11-096
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.013433

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 PROJECT: NYC DEP, 29 Park Row
 DATE OF REPORT: 11/2/02
 DATE OF ANALYSIS: 11/2/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	G.O.'s ANALYZED	AREA ANALYZED (m ²)	ANALYT. SENSITV. (ft ³ /cm ³)	TOTAL ASBESTOS AIR CONC. (ft ³ /cm ³)	TOTAL ASBESTOS FILTER CONC. (ft ³ /mm ²)	AIR CONC. FOR STRUCT. 0.45-5µm	AIR CONC. FOR STRUCT. ≥5µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01TWA	T02-11-096-4191	TWA on roof center of WA	1320	5	0.0672	0.0043	<0.0043	<14.89	NA	NA	NA	NA
02TWA	T02-11-096-4192	TWA on roof north west section of WA	1320	5	0.0672	0.0043	<0.0043	<14.89	NA	NA	NA	NA
03TWA	T02-11-096-4193	TWA on roof south east section of WA	1320	5	0.0672	0.0043	<0.0043	<14.89	NA	NA	NA	NA
04TWA	T02-11-096-4194	TWA on roof 6ft of door entrance to roof	1320	5	0.0672	0.0043	0.0087	29.78	0.00887	<0.0043	Chrys.	NA
05OWA	T02-11-096-4205	OWA on stair well leading to roof door entrance	1320	5	0.0672	0.0043	<0.0043	<14.89	NA	NA	NA	NA

E. Sioulki

 ANALYST
 E. Sioulki

Sam D. Dargatzis

 LABORATORY DIRECTOR
 Spiro Dargatzis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Alternata Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Alternata Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

SEE REVERSE SIDE FOR ANALYSIS INFORMATION