

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079 01.02

21 Ann Street 111 Nassau

Received: 6/29/02

5:00:00 PM


ATC Group #: 8335

Analysis Date: 6/30/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 8335 -1	1500.00	0.0562	0	CHRYSTILE	0 1	0.0046	17.79 0.0046	
02 8335 -2	1500.00	0.0562	0	CHRYSTILE	2 0	0.0046	35.59 0.0091	
03 8335 -3	1491.00	0.0562	0	CHRYSTILE	1 0	0.0046	17.79 0.0046	
04 8335 -4	1479.00	0.0562	0	None Detected	0 0	0.0046	<17.75 <0.0046	
05 8335 -5	1362.00	0.0674	0	CHRYSTILE	1 1	0.0042	29.66 0.0084	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

44

228 East 43rd Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0030

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8335

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE ____ OF ____

P.O. ____

CONTACT: PTKGS 46444

CLIENT: DGP

PROJECT: FAADE / ROOF CLEANUP

LOCATION: 31-BAY III MASSA

W&P FILE #: 1079 01-02

LABORATORY: HTC

ANALYSIS METHOD: PCM

circle one

TECHNICIAN: John Burgess

TEM

AHERA

EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
01	Upper East by SASH - Along	3	5	5	8 45	13 15	300	15.00
02	Upper East by SASH - Along	3	5	5	8 50	13 50	300	15.00
03	Upper East by SASH - Along	3	5	5	8 54	13 51	298.2	14.91
04	Upper East by SASH - Along	3	5	5	8 59	13 52	295.8	14.79
05	Upper East by SASH - Along	3	5	5	9 00	13 54	272.4	13.62
06	FIELD BLANK	1						
07	FIELD BLANK	1						

COMMENTS:

SAMPLE BY: <u>John Burgess</u>	DATE: <u>06/29/02</u>
SIGNATURE: <u>John Burgess</u>	DATE: <u>06/29/02</u>
RELEASED BY: <u>John Burgess</u>	DATE: <u>06/29/02</u>
SIGNATURE: <u>John Burgess</u>	DATE: <u>06/29/02</u>
RECEIVED BY: <u>H. Gray</u>	
SIGNATURE: <u>H. Gray</u>	

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8335

Date: Sunday, June 30, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street 111 Nassau

Time: 12:16:24 PM

Number of Pages: 3
(including cover page)

Comments:

43