

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/29/02 5:00:00 PM
ATC Group #: 8336
Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077
Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street, Roof Cleaning

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8336 -1	1350.00	0.0674	0	CHRYSTILE	3	1	0.0042	59.31	0.0169
02 8336 -2	1350.00	0.0674	0	CHRYSTILE	2	0	0.0042	29.66	0.0085
03 8336 -3	1350.00	0.0674	0	CHRYSTILE	1	1	0.0042	29.66	0.0085
04 8336 -4	1350.00	0.0674	0	CHRYSTILE	7	3	0.0042	148.28	0.0423
05 8336 -5	1350.00	0.0674	0	CHRYSTILE	2	2	0.0042	59.31	0.0169
04QC 8336 -6	1350.00	0.0674	0	CHRYSTILE	3	3	0.0042	88.97	0.0254

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by: _____

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101167-3, NY State ELAP #10879

23

Page 1 of 1

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/29/02 5:00:00 PM
 ATC Group #: 8336
 Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 21 Ann Street, Roof Cleaning

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
01 8336 -1	1350.00	0.0674	0	CHRYSTILE	3	1	0.0042	59.31 0.0169
02 8336 -2	1350.00	0.0674	0	CHRYSTILE	2	0	0.0042	29.66 0.0085
03 8336 -3	1350.00	0.0674	0	CHRYSTILE	1	1	0.0042	29.66 0.0085
04 8336 -4	1350.00	0.0674	0	CHRYSTILE	7	3	0.0042	148.28 0.0423
05 8336 -5	1350.00	0.0674	0	CHRYSTILE	2	2	0.0042	59.31 0.0169
04QC 8336 -6	1350.00	0.0674	0	CHRYSTILE	3	3	0.0042	88.97 0.0254 Reanalysis

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

PAGE 1 OF 1

P.O.

CONTACT:

W&P FILE #: 1079.01.02

LABORATORY:

ANALYSIS METHOD: PCM
circle one

~~AMERA~~ EPA LEVEL II

TECHNICIAN: *Louis Soto*

COMMENTS:

SAMPLE BY: <u>Louis Soto</u>	DATE: <u>6-29-02</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>Louis Soto</u>	DATE: <u>6-29-02</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: _____	DATE: <u>06/29/02</u>
SIGNATURE: <u>M. Brey</u>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Podone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8336

Date: Monday, July 01, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street, Roof Cleaning

Time: 10:11:00 PM

Comments:

Number of Pages: 3
(including cover page)

22