

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedene

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/2/02

5:50:00 PM

ATC Group #: 8381

Analysis Date: 7/3/02

Project: NYC- DEP W & P File # 1079.01.02

21 Ann Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
JB70202-1 8381 -1	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046
JB70202-2 8381 -2	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046
JB70202-3 8381 -3	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046
JB70202-4 8381 -4	1500.00	0.0562	0	None Detected	0 0	0.0046	<17.79	<0.0046
JB70202-5 8381 -5	1350.00	0.0674	0	None Detected	0 0	0.0042	<14.83	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

W&P FILE #: 1079-01-92

CONTACT: Mike Nolas

CLIENT: NYC DEP

PROJECT: 41 Ave St

LOCATION: 6000

LABORATORY: APC

ANALYSIS METHOD: PCM TEM TEM

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN:

2381

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
5070202-1	inside rept door	TEM		10 19	0832 1109	150	1500	
5070202-2	North side roof	TEM		10 19	0832 1102	150	1500	
5070202-3	South side roof	TEM		10 10	0834 1104	150	1500	
5070202-4	West side roof	TEM		10 10	0830 1106	130	1500	
5070202-5	East side roof	TEM		10 10	0930 1143	135	1750	
5070202-6	Field blank	NA		NA NA	0 0	0	0	
5070202-7	11	NA		NA NA	0 0	0	0	
5070202-8	Sealed blank	NA		NA NA	0 0	0	0	

COMMENTS:

SAMPLE BY: John Bayard	DATE: 7-22-02
SIGNATURE: <i>John Bayard</i>	
RELEASED BY: John Bayard	DATE: 7-22-02
SIGNATURE: <i>John Bayard</i>	
RECEIVED BY: Michael APC	DATE: 7/22/02 4:50 PM
SIGNATURE: <i>Michael APC</i>	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8381

Fax #: (212) 922-0630

Client Project: NYC- DEP W & P File # 1079.01.02
21 Ann Street

Date: Wednesday, July 03, 2002

Time: 2:40:03 PM

Number of Pages: 3
(including cover page)

Comments: