

**ATC Associates**

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren &amp; Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W &amp; P File #. 1079 01.02

21 Ann Street 111 Nassau

Received: 6/29/02

5:00:00 PM

ATC Group #: 8335

Analysis Date: 6/30/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed  
by EPA 40 CFR Part 763 Final Rule (AHERA)**

| Sample        | Volume  | Area<br>Analyzed | Non<br>Asb | Asbestos<br>Type(s) | # Structures<br>0.5µ-5 µ | Analytical<br>Sensitivity<br>(S/cc) | Asbestos<br>Concentration<br>(S/mm <sup>3</sup> ) | (S/cc) | Notes   |
|---------------|---------|------------------|------------|---------------------|--------------------------|-------------------------------------|---------------------------------------------------|--------|---------|
| 01<br>8335 -1 | 1500.00 | 0.0562           | 0          | CHRYSTILE           | 0                        | 1                                   | 0.0046                                            | 17.79  | 0.0046  |
| 02<br>8335 -2 | 1500.00 | 0.0562           | 0          | CHRYSTILE           | 2                        | 0                                   | 0.0046                                            | 35.59  | 0.0091  |
| 03<br>8335 -3 | 1491.00 | 0.0562           | 0          | CHRYSTILE           | 1                        | 0                                   | 0.0046                                            | 17.79  | 0.0046  |
| 04<br>8335 -4 | 1479.00 | 0.0562           | 0          | None Detected       | 0                        | 0                                   | 0.0046                                            | <17.79 | <0.0046 |
| 05<br>8335 -5 | 1362.00 | 0.0674           | 0          | CHRYSTILE           | 1                        | 1                                   | 0.0042                                            | 29.66  | 0.0084  |

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm<sup>3</sup>. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101167-0, NY State ELAP #10879

44





**ATC Associates Inc.**

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

---

***FACSIMILE TELECOPY TRANSMISSION***

To: Mr. Fabio Pedone  
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8335

Date: Sunday, June 30, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02  
21 Ann Street 111 Nassau

Time: 12:16:24 PM

Number of Pages: 3  
(including cover page)

Comments:

43