

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/29/02

5:00:00 PM

ATC Group #: 8336

Analysis Date: 6/30/02

Project: NYC-DEP W & P File #: 1079 01.02

21 Ann Street, Roof Cleaning

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
01 8336 -1	1350.00	0.0674	0	CHRYSTILE	3	1	0.0042	59.31 0.0169
02 8336 -2	1350.00	0.0674	0	CHRYSTILE	2	0	0.0042	29.66 0.0085
03 8336 -3	1350.00	0.0674	0	CHRYSTILE	1	1	0.0042	29.66 0.0085
04 8336 -4	1350.00	0.0674	0	CHRYSTILE	7	3	0.0042	148.28 0.0423
05 8336 -5	1350.00	0.0674	0	CHRYSTILE	2	2	0.0042	59.31 0.0169

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-C, NY State ELAP #10879

6

220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8336

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

PAGE 1 OF 1

P.O.

CONTACT:

WSP FILE #: 1079.01.02

LABORATORY:

CLIENT: NYC DEP
PROJECT: Roof Cleanup
LOCATION: 21 Ann St.

ANALYSIS METHOD: PCM 7400 TEM
circle one AHERA EPA LEVEL II

TECHNICIAN: Louis Soto

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)
01	ON ROOF NEAR W. WALL	3	01	5 5	930	1400	270	1350	
02	ON ROOF NEAR E. WALL	3	02	5 5	931	1401	270	1350	
03	ON ROOF IN CENTER	3	03	5 5	932	1402	270	1350	
04	ON ROOF 10 FT. FROM SAMPLE 03	3	04	5 5	933	1403	270	1350	
05	ON FIRE ESCAPE OFF ROOF	3	05	5 5	934	1404	270	1350	
06	FIELD BLANK	1							
07	FIELD BLANK	1							
08	CANED BLANK	1							

COMMENTS:

SAMPLE BY: Louis Soto DATE: 6.23.02
 SIGNATURE: *[Signature]*
 RELEASED BY: Louis Soto DATE: 6.25.02
 SIGNATURE: *[Signature]*
 RECEIVED BY: *[Signature]* DATE: 06/29/02
 SIGNATURE: M. Brody

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8336

Date: Sunday, June 30, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street Roof Cleaning

Time: 12:17:38 PM

Number of Pages: 3
(including cover page)

Comments:

5

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/29/02 5:00:00 PM

ATC Group #: 8336

Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street, Roof Cleaning

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µm-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
01 8336 -1	1350.00	0.0674	0	CHRYSTILE	3	1	0.0042	59.31 0.0169
02 8336 -2	1350.00	0.0674	0	CHRYSTILE	2	0	0.0042	29.66 0.0085
03 8336 -3	1350.00	0.0674	0	CHRYSTILE	1	1	0.0042	29.66 0.0085
04 8336 -4	1350.00	0.0674	0	CHRYSTILE	7	3	0.0042	148.28 0.0423
05 8336 -5	1350.00	0.0674	0	CHRYSTILE	2	2	0.0042	59.31 0.0169
04QC 8336 -6	1350.00	0.0674	0	CHRYSTILE	3	3	0.0042	88.97 0.0254

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI Ph.D.

Approved by: _____

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101167-0, NY State ELAP #10579

23

Page 1 of 1

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

21 Ann Street, Roof Cleaning

Received: 6/29/02

5:00:00 PM

ATC Group #: 8336

Analysis Date: 7/1/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8336 -1	1350.00	0.0674	0	CHRYSTILE	3	1	0.0042	59.31	0.0169
02 8336 -2	1350.00	0.0674	0	CHRYSTILE	2	0	0.0042	29.66	0.0085
03 8336 -3	1350.00	0.0674	0	CHRYSTILE	1	1	0.0042	29.66	0.0085
04 8336 -4	1350.00	0.0674	0	CHRYSTILE	7	3	0.0042	148.28	0.0423
05 8336 -5	1350.00	0.0674	0	CHRYSTILE	2	2	0.0042	59.31	0.0169
04QC 8336 -6	1350.00	0.0674	0	CHRYSTILE	3	3	0.0042	88.97	0.0254 Reanalysis

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

PAGE 1 OF 1

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8336

P.O.

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

W&P FILE #: 1079. 01.02

CONTACT:

CLIENT: NYC DEP

PROJECT: Roof Cleanup

LOCATION: 21 Ann St.

LABORATORY:

ANALYSIS METHOD: PCM
circle one 7400 TEM
ANHERA EPA LEVEL II

TECHNICIAN: Luis Soto

97093-97100

[illegible]

COMMENTS:

SAMPLE BY: Louis Soto	DATE: 6-29-02
SIGNATURE: 	
RELEASED BY: Louis Soto	DATE: 6-29-02
SIGNATURE: 	
RECEIVED BY:	DATE: 06/29/02
SIGNATURE: 	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Podone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8336

Date: Monday, July 01, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
21 Ann Street, Roof Cleaning

Time: 10:11:00 PM

Number of Pages: 3

(including cover page)

Comments:

22