

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedene
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/2/02 5:50:00 PM
 ATC Group #: 8381
 Analysis Date: 7/3/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC- DEP W & P File # 1079.01.02
 21 Ann Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
JB70202-1 8381 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-2 8381 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-3 8381 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-4 8381 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
JB70202-5 8381 -5	1350.00	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

448 East 40th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-8630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

W&P FILE #: 1079-01-92

CONTACT: Mike Nolasco

CLIENT: NYC D E D
PROJECT: 4 Ave 57
LOCATION: 900

LABORATORY: APC

ANALYSIS METHOD: PCM TEM JEM
7400 AHERA EPA LEVEL II

TECHNICIAN: 2381

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (µg/cc.)
5070202-1	inside roof Door	TEM		10	19	0839	1100	150	1500	
5070202-2	North side roof	TEM		10	19	0832	1102	150	1500	
5070202-3	South side roof	TEM		10	10	0834	1104	160	1600	
5070202-4	West side roof	TEM		10	10	0830	1106	130	1300	
5070202-5	East side roof	TEM		10		0930	1143	135	1350	
5070202-6	Field Blank	NA		NA	NA	0	0	0	0	
5070202-7	Blank	NA		NA	NA	0	0	0	0	
5070202-8	Sealed Blank	NA		NA	NA	0	0	0	0	

COMMENTS:

SAMPLE BY: John Bryant DATE: 7.26.02
SIGNATURE: [Signature]
RELEASED BY: John Bryant DATE: 7.26.02
SIGNATURE: [Signature]
RECEIVED BY: Michael [Signature] DATE: 7/26/02
SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8381

Fax #: (212) 922-0630

Client Project: NYC- DEP W & P File # 1079.01.02
21 Ann Street

Date: Wednesday, July 03, 2002

Time: 2:40:03 PM

Number of Pages: 3

(including cover page)

Comments: