


**New York City
Department of Transportation**

BOROUGH : MANHATTAN
136
INSPECT DIST: 3

35

PERMIT # : M02-2002210-

RECORDED # : NONE
PREVIOUS # : M02-2002210-1

BUILDING OPERATION PERMIT
PERMIT VALID FROM 07/29/2002 TO 08/30/2002

FEES (NON-REFUNDABLE):

ADMIN \$**50.00
REISSUE

PERMIT TYPE 0214
PAVEMENT TYPE ASPHALT
SIDEWALK TYPE
ISSUE DATE 07/29/2002

TOTAL FEE \$****50.00 FEE WAIVED

PERMISSION HEREBY GRANTED TO :

NAME : BENJAMIN KURZBAN & SON CONTROL
CONTACT NAME : MITCHELL KURZBAN
PHONE : (718) 531 - 2900
ADDRESS : 1248 RALPH AVENUE BROOKLYN NY 11236
GENERAL CONTRACTOR

LICENSE # :
PERMITTEE # : 12470
CONTRACT # : R0F-REM

TO OCCUPY THE ROADWAY IN FRONT OF :

HOUSE # : 35
ON STREET : ANN STREET
FROM STREET : NASSAU STREET
TO STREET : WILLIAM STREET

FOR THE PURPOSE OF : PLACE CONTAINER ON THE STREET
BLDG EXTERIOR CLEANUP ACTIVITIES TO REMOVE DEBRIS
FROM COLLAPSE OF WTC

*** SEE PAGE 2 FOR STIPULATIONS ***

PERMIT ORIGINALLY PRINTED ON 07/29/2002 AT 15:44 BY CANDANCE CAVARRETTA PERMIT OFF

PAGE 1 OF 2

PERMITTEES SHALL COMPLY WITH ALL APPLICABLE LAWS,
RULES AND SPECIFICATIONS OF THE NEW YORK CITY
DEPARTMENT OF TRANSPORTATION AND WITH THE TERMS
AND CONDITIONS OF THE PERMIT. FAILURE TO COMPLY
MAY RESULT IN REVOCATION OF THE PERMIT BY THE COM-
MISSIONER.


COMMISSIONER

PER _____

Asbestos Inspection Report

FINAL

Premise No. 35 ANN STREET					Inspection Date: 06-23-02	
Floor ROOF	Zip	Borough 1	Block 92	Lot 23	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken Yes ☒ No ☐
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: 7 ⁰⁰ AM - 3 ⁰⁰ PM		

7:00AM I REQUEST AND I AM PRESENTED WITH VALID NYCDOP AND NYS DOL ASBESTOS HANDLER/ SUPERVISOR CERTIFICATES FOR ALL WORKERS INVOLVED AT THE JOBSITE.

8:00AM WORKERS BEGIN SETTING UP OF PLASTIC DYKE TO COLLECT ANY RUN-OFF WATER FROM THE FACADE CLEAN UP OF THIS PREMISE.

8:35AM FILTRATION SYSTEM FOR THE RUN-OFF WATER IS IN PLACE.

9:25 AM - 10:15 AM WARREN & PANZER REPRESENTATIVE BEGINS AIR SAMPLING FOR THIS PROJECT. FOR THE PURPOSES OF AIR SAMPLING THE FACADE OF 35 ANN STREET AND 45 ANN STREET WILL BE CONSIDERED ONE WORK AREA. FIVE AIR SAMPLES COLLECTIVELY ARE RUN FOR THESE TWO WORK AREAS. LOCATIONS ARE AS FOLLOWS: 1 @ DECON UNIT, 2 ON THE SIDE WALL JUST OUTSIDE THE WORK AREA AND 2 ON THE ROOF OF 45 ANN (MID W&P REP: LARRY BAER FLOW RATE: 3 LITERS/MIN.

12:00PM WORKERS HAVE COMPLETED THE FACADE CLEAN UP OF 35 ANN STREET. A VISUAL INSPECTION WILL BE CONDUCTED WHEN THE FACADE IS COMPLETELY DRY.

3:00PM I CONDUCT A VISUAL INSPECTION OF THE FACADE OF 35 ANN STREET. WORK AREA IS FOUND TO BE CLEAN. VISUAL INSPECTION IS PASSED. BOTH FACADE AND ROOF AREAS HAVE BEEN CLEANED. THE PROJECT IS NOW COMPLETED.