

Building #100

- 345 South End Ave

- The summary results for bulk sampling match what I found in my computation.
(40 bulk samples $< 1\%$)
- The report indicates 29 air samples, however I find 32 air samples $< 70 \text{ f}/\text{mm}^2$

Bulk Sampling results Building #100
345 South End Ave

<u>Floor #</u>	<u>Total Samples</u>	<u>Results</u>
3	9	<1%
4	10	<1%
5	9	<1%
6	7	<1%
<u>7</u>	<u>5</u>	<1%
Σ = 5 floor	Σ = 40 samples	

Air Sampling Results

Building #100
345 South End Ave

<u>Floor #</u>	<u>Total Samples</u>	<u>Results</u>
----------------	----------------------	----------------

1	2	< 70 f/min ²
---	---	-------------------------

2	4	" "
---	---	-----

3	5	" "
---	---	-----

4	8	" "
---	---	-----

5	5	" "
---	---	-----

6	5	" "
---	---	-----

7	3	" "
---	---	-----

floor 7

Σ = 32
samples