

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/13/02

7:00:00 PM

ATC Group #: 8091

Analysis Date: 6/14/02

Project: NYC-DEP W & P File #: 1079.01.02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
025 8091 -1	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
026 8091 -2	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
027 8091 -3	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
028 8091 -4	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049
029 8091 -5	1400.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

8091

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

०३

CLIENT:

24

PROJECT: 23 Trinity PL / 47 Broadview
LOCATION: Rest

W&P FILE #: 1079.01.02

TURN AROUND: 24 hrs

TECHNICIAN: FALCONER

Analysis Method: PCM - 7400
(circle one) ~~DEM - AHER~~

TEM - EPA LEVEL II

[illegible]

SAMPLED BY:	LEN SAMANTER	DATE:	6/13/82
SIGNATURE:	<i>[Signature]</i>		
RELEASED BY:	LEN SAMANTER	DATE:	6/13/82
SIGNATURE:	<i>[Signature]</i>		
RECEIVED BY:	<i>[Signature]</i>	DATE:	6/13
SIGNATURE:	<i>[Signature]</i>		13:000

SAMPLE TYPE CODES-

1 - Blank

2 - Pre-Abatement

3 - During Abatement

4 - During Glove Bag Removal

5 - Final Clearance (Ins/de)

8 - Final Clearance (outside)

7 - Personal

Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION