

47 Broadway

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

23-25 Trinity Place, Front Façade

Received: 6/29/02

6:00:00 PM

ATC Group #: 8339

Analysis Date: 6/30/02


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
JB62902-1 8339 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
JB62902-2 8339 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
JB62902-3 8339 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
JB62902-4 8339 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
JB62902-5 8339 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-G, NY State ELAP #10879

50

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-9630

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

8339

24 hr⁺/a

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC DEP

W&P FILE #: 1279.01.02

CONTACT: Mike Nolan

PROJECT: 22-25 Trinity Pl

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM
circle one 7403 AHRA EPA LEVEL II

LOCATION: 4th floor 4ac cd

TECHNICIAN:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
JB62902.1	By Dec on (in truck)	TEM		5	5	1000	1600	360	1800	
JB62902.2	by side of 23 Trinity Pl	TEM		5	5	1002	1602	360	1800	
JB62902.3	in front of 23 Trinity Pl	TEM		5	5	1004	1604	360	1800	
JB62902.4	in front of 25 Trinity Pl	TEM		5	5	1006	1606	360	1800	
JB62902.5	by side of 25 Trinity Pl	TEM		5	5	1008	1608	360	1800	
JB62902.6	Field Blank	NA		NA	NA	0	0	0	0	
JB62902.7	"	NA		NA	NA	0	0	0	0	
JB62902.8	Graded Blank	NA		NA	NA	0	0	0	0	

COMMENTS:

SAMPLE BY: John Boyd	DATE: 6-29-02
SIGNATURE: [Signature]	
RELEASED BY: John Boyd	DATE: 6-29-02
SIGNATURE: [Signature]	
RECEIVED BY: [Signature]	DATE: 6/29/02
SIGNATURE: M. Boyd	

SAMPLE TYPE CODES			
1 - Blank	2 - Pre-Abatement	5 - Final Clearance (inside)	
3 - During Abatement	4 - During Glove Bag Removal	6 - Final Clearance (outside)	
		7 - Personal	
		8 - Background	

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8339

Date: Sunday, June 30, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
23-25 Trinity Place, Front Facade

Time: 12:18:30 PM

Comments:

Number of Pages: 3
(including cover page)

49