

PROJECT: NYC DEP, 50 Broadway.
DATE OF REPORT: 08/26/02
DATE OF ANALYSIS: 08/25/02
EFFECTIVE FILTER AREA (mm²): 385

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-08-126
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (mm²): 0.012422



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7400
Fax. (718) 784-4085

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (street/cm ²)	TOTAL ASBESTOS AIR CONC (street/cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR STRUCT. 0.5 <= 5µm	AIR CONC. FOR STRUCT. >= 5.0µm	ASBEST. TYPE CHRVS.	AMPHIB. ASBEST. TYPE SPECIFY
B 01	T02-08-126-1869	On left side of New street (North end)	1260	6	0.0745	0.0041	<0.0041	<13.42	NA	NA	NA	NA
B 02	T02-08-126-1870	On right side of New street (North end)	1260	6	0.0745	0.0041	<0.0041	<13.42	NA	NA	NA	NA
B 03	T02-08-126-1871	At center of New street	1260	6	0.0745	0.0041	<0.0041	<13.42	NA	NA	NA	NA
B 04	T02-08-126-1872	On left side of New street (South end)	1260	6	0.0745	0.0041	<0.0041	<13.42	NA	NA	NA	NA
B 05	T02-08-126-1873	On right side of New street (South end)	1260	6	0.0745	0.0041	<0.0041	<13.42	NA	NA	NA	NA

Sam Spiro

ANALYST
E. Sivukri

Sam Spiro

LABORATORY DIRECTOR
Spiro Douglas

LABORATORY CERTIFICATION STATEMENT

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassette will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athena Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0530

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

PAGE 1 OF 1

W&P FILE #: 1077-01-02

CONTACT: M. Nolan

LABORATORY:

CLIENT: NYC DEP
PROJECT: 11 Avenue #7
LOCATION: 50 Broadway New York
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II
TECHNICIAN: Chetam Ramraj

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb./cc.)
B01	On left side of New Street (westward)	3		4	4	11:20	16:35	315	1260	
B02	On right side of New Street (westward)	3		4	4	11:21	16:36			
B03	At Centre of New St	3		4	4	11:22	16:37			
B04	On left side of New St (south end)	3		4	4	11:23	16:38			
B05	On right side of New St (south end)	3		4	4	11:24	16:39			
B06	Free lot									
B07	Blank									
B08										

SAMPLE BY: Chetam Ramraj DATE: 8/24/02
SIGNATURE: Chetam Ramraj
RELEASED BY: Chetam Ramraj DATE: 8/24/02
SIGNATURE: Chetam Ramraj
RECEIVED BY: A. J. GAL DATE: 8/24/02
SIGNATURE: A. J. GAL

102-08-126

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION