


ATHENICA

 ENVIRONMENTAL SERVICES INC.
 Tel. (718) 784-7490
 Fax. (718) 784-4085

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 CLIENT: Warren & Panzer Engineers, P.C.
 LABORATORY ID #: T02-08-127
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.012422
 PROJECT: NYC DEP, 50 Broad St.
 DATE OF REPORT: 08/25/02
 DATE OF ANALYSIS: 08/25/02
 EFFECTIVE FILTER AREA (mm²): 185

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struck/cm ²)	TOTAL ASBESTOS AIR CONC. (struck/cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR 0.55-5µm	AIR CONC. FOR 5-5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-08-127-1874	Roof- South	1200	6	0.0745	0.0043	<0.0043	<13.42	NA	NA	NA	NA
02	T02-08-127-1875	Roof- West	1200	6	0.0745	0.0043	<0.0043	<13.42	NA	NA	NA	NA
03	T02-08-127-1876	Roof - North	1200	6	0.0745	0.0043	<0.0043	<13.42	NA	NA	NA	NA
04	T02-08-127-1877	Street level- North	1200	6	0.0745	0.0043	<0.0043	<13.42	NA	NA	NA	NA
05	T02-08-127-1878	Street level- South	1200	6	0.0745	0.0043	<0.0043	<13.42	NA	NA	NA	NA

 ANALYST
 E. Siadkri

 LABORATORY DIRECTOR
 Spiro Doagaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0639**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

CLIENT: DEP
PROJECT: 50 GRAND STREET
LOCATION: ROXR FENADE

LABORATORY: TEM
ANALYSIS METHOD: PCM
circle one 7460 AHERA EPA LEVEL II

CONTACT:

TECHNICIAN: B. OGURA/AFK.C

[illegible]

REMARKS.

102-08-127

SAMPLE BY: B. R. ^{Signature} DATE: 8/24/62

SIGNATURE: [Signature]

RELEASED BY: _____ DATE: _____

SIGNATURE: _____

RECEIVED BY: A. G. ADJICAL ^{Signature} DATE: 8/25/62

SIGNATURE: [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION