

10/23/2002 15:22 FAX

020

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7498
Fax. (718) 784-4085

CLIENT: Warren & Pitzer Engineers, P.C.

LABORATORY ID #: T02-10-149

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, NYU Hospital

DATE OF REPORT: 10/22/02

DATE OF ANALYSIS: 10/22/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (M)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (street/cm ³)	TOTAL ASBESTOS AIR CONC. (true/cm ³)	TOTAL ASBESTOS FILTER CONC. (air/mm ²)	AIR CONC. FOR 0.55-5µm	AIR CONC. FOR S2.50µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-149-3447	North area	1440	4	0.0554	0.0048	<0.0048	<18.07	NA	NA	NA	NA
02	T02-10-149-3448	West area	1440	4	0.0554	0.0048	<0.0048	<18.07	NA	NA	NA	NA
03	T02-10-149-3449	South area	1440	4	0.0554	0.0048	<0.0048	<18.07	NA	NA	NA	NA
04	T02-10-149-3450	East area	1440	4	0.0554	0.0048	<0.0048	<18.07	NA	NA	NA	NA
05	T02-10-149-3451	Middle area	1440	4	0.0554	0.0048	<0.0048	<18.07	NA	NA	NA	NA

ANALYST
E. SioukriLABORATORY DIRECTOR
Spiro Dongaris**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

2220 East 45th Street
New York, NY 10017
(212) 922-0677
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

Immediate +/a
3 hr⁺/a
6 hr⁺/a
12 hr⁺/a
24 hr⁺/a

W&P FILE #: 1079 . 01 . 02

LABORATORY:

CLIENT: DEP

PROJECT: facade cleaning

LOCATION: 2: 5: 5: Hospital

ANALYSIS METHOD:	PCM	TEM
ANALYSIS METHOD:	PCM	TEM

circle one **7400** **ANHERA** **EPA LEVEL II**

TECHNICIAN: RONALD K. JONES

1

THE	Y	Y	Y
-----	---	---	---

[illegible]

SECRET

SAMPLE BY: <u>Ronald King</u>	DATE: <u>10/22/66</u>
SIGNATURE: <u>Ronald King</u>	
RELEASED BY: _____	DATE: _____
SIGNATURE: _____	
RECEIVED BY: <u>A. C. IGA</u>	DATE: <u>10/22/66</u>
SIGNATURE: <u>A. C. IGA</u>	

T02-10-149

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION