

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 56 Beaver

Received: 6/27/02 7:00:00 PM
 ATC Group #: 8307
 Analysis Date: 6/28/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
JB62702-1 8307 -1	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
JB62702-2 8307 -2	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
JB62702-3 8307 -3	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
JB62702-4 8307 -4	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
JB62702-5 8307 -5	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

8307

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

~~24 hr⁺/a~~ 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

PAGE 1 OF 1

2.

CONTACT: MIKE WALSH

W&P FILE #: 1079-91-92

LABORATORY: ATC

ANALYSIS METHOD:	PCM	TEM	TEM
------------------	-----	-----	-----

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN:

CLIENT: NYC DEP
PROJECT: 484 N 56 Beaver
LOCATION: 29th

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (Mets)	CONCENTR. (lb./cc.)
JB62702-1	JWA	TEM		4 4	1030 1600	330	1320	
JB62702-2	JWA	TEM		4 4	1032 1602	330	1320	
JB62702-3	By Design	TEM		4 4	1034 1604	330	1320	
JB62702-4	Inside Door	TEM		4 4	1036 1606	330	1320	
JB62702-5	on the OH Floor	TEM		4 4	1038 1608	330	1320	
JB62702-6	Field Blank	NA		NA NA	0 0	0	0	
JB62702-7	u	NA		NA NA	0 0	0	0	
JB62702-8	Sealed Blank	NA		NA NA	0 0	0	0	

COMMENTS:

SAMPLE BY: John Boyd DATE: 6-29-68
SIGNATURE: [Signature]
RELEASED BY: John Boyd DATE: 6-29-68
SIGNATURE: [Signature]
RECEIVED BY: _____ DATE: _____
SIGNATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEP REVERSE SIDE FOR ANALYSIS INFORMATION