

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/20/02

8:00:00 PM

ATC Group #: 8198

Analysis Date: 6/21/02

Project: NYC-DEP W & P File #: 1079.01.02

Roof Cleaning

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
25 8198 -1	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
26 8198 -2	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
27 8198 -3	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
28 8198 -4	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
29 8198 -5	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879


Roof Cleaning

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
25 8198 -1	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
26 8198 -2	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
27 8198 -3	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
28 8198 -4	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043
29 8198 -5	1320.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

CLIENT: NYC-DEP

PROJECT: ROOF CLEANING

LOCATION: S BEEKMAN ST

W&P FILE #: 1079.01.02

LABORATORY: A-TC

ANALYSIS METHOD: PCM TEM

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: FAYED EL-GHENDY

CONTACT: NELSON

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
25	WORK AREA RIGHT	3		2 2	0810 1910	660	1320	
26	WORK AREA LEFT				0810 1910			
27	ACCESS DOOR TO THE ROOF				0811 1911			
28	ONE FLOOR BELOW THE ROOF				0812 1912			
29	THE DECK	3		2 2	0812 1912	660	1320	
30	F. BLANK							
31	F. BLANK							
32	F. BLANK							

COMMENTS:

SAMPLE BY: FAYED EL-GHENDY	DATE: 6-20-02
SIGNATURE: F. El-Ghendi	
RELEASED BY: FAYED EL-GHENDY	DATE: 6-20-02
SIGNATURE: F. El-Ghendi	
RECEIVED BY: J. J. J.	DATE: 6/20
SIGNATURE: [Signature]	DATE: 6/20

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (Inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION