

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

5 Beekman Street

Received: 6/21/02

7:00:00 PM

ATC Group #: 8217

Analysis Date: 6/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
33 8217 -1	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
34 8217 -2	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
35 8217 -3	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
36 8217 -4	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041
37 8217 -5	1680.00	0.0562	0	None Detected	0	0	0.0041	<17.79	<0.0041

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

W&P FILE #: 1074. 01.02

CONTACT:

4057-3

LABORATORY: *W&F*

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	AHERA	EPAL LEVEL II

ANHEPA (EPA LEVEL II)

TECHNICIAN: RAYD. EL-GENDI

[illegible]

COMMENTS:

SAMPLE BY: FAVED EL-GARDI DATE: 6.21.02
SIGNATURE: F. El-Gardi
RELEASED BY: FAVED EL-GARDI DATE: 6.21.02
SIGNATURE: F. El-Gardi
RECEIVED BY: [Signature] DATE: 6/21/02
SIGNATURE: H. G. [Signature]

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers . P.C.

Fax #: (212) 922-0630

Date: Saturday, June 22, 2002

Time: 9:29:21 AM

Comments:

From: MARK PEYSAKHOV

ATC Group #: 8217

Client Project: NYC-DEP W & P File #: 1079.01.02
5 Beekman Street

Number of Pages: 3
(including cover page)