

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

123 / 119 Nassau Street

Received: 6/28/02

8:00:00 PM

ATC Group #: 8327

Analysis Date: 6/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/min ²)	Notes
01 8327 -1	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
02 8327 -2	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
03 8327 -3	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
04 8327 -4	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
05 8327 -5	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependant on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/min². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

17

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0670

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.O.

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: DEP

PROJECT: SE 111-119 Nassau

LOCATION: 12.3 / 119 Nassau

W&P FILE #: 1079 of 22

LABORATORY: ATC

ANALYSIS METHOD: PCM
circle one 7400

TEM
AHRA EPA LEVEL II

CONTACT: W&P

TECHNICIAN: J. BURGESS

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (Mb./cc.)
01	DECON-	3		4	4	10 45	17 45	120	1680	
02	LOT AREA BY DECON	3		4	4	10 48	17 48	120	↑↑	
03	LOT AREA 12' FROM DECON	3		4	4	10 52	17 52	120	↑↑	
04	LOT AREA 70' FROM DECON - 10' FROM DECON	3		4	4	10 55	17 55	120	↑↑	
05	C DECON	3		4	4	10 58	17 58	120	1680	
06	FIELD BLANK	1		~	~	---	---	---	---	---
07	FIELD BLANK	1		~	~	---	---	---	---	---

COMMENTS:

SAMPLE BY: John D. Burgess DATE: 06-20
SIGNATURE: [Signature]
RELEASED BY: J. A. Burgess DATE: 06-28
SIGNATURE: [Signature]
RECEIVED BY: N. Burgess DATE: 06/20/02
SIGNATURE: [Signature]

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ADDITIONAL INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8327

Date: Saturday, June 29, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
123 / 119 Nassau Street

Time: 12:54:25 PM

Comments:

Number of Pages: 3
(including cover page)

10