

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
5 Beekman

Received: 7/13/02

1:30:06 PM

ATC Group #: 8477

Analysis Date: 7/13/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8477 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
02 8477 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
03 8477 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
04 8477 -4	1500.00	0.0562	0	CHRYSTOLE	2	0	0.0046	35.59	0.0091
05 8477 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

AIR MONITORING LOG SHEET/CHAIR-2

CLIENT: NYCB
PROJECT: Scaffold
LOCATION: 5 Beekm

LABORATORY: ATC

ANALYSIS METHOD: PCM 7400

TECHNICIAN: L. J. JTD

[illegible]

COMMENTS:

SAMPLE BY:	Louis Soto	DATE:	7-12-02
SIGNATURE:	<i>[Signature]</i>	DATE:	7-12-02
RELEASED BY:	Louis Soto	DATE:	7/13/02
SIGNATURE:	<i>[Signature]</i>	DATE:	7/13/02
RECEIVED BY:	AIC	DATE:	7/30/02
SIGNATURE:	<i>[Signature]</i>	DATE:	7/30/02

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Wednesday, July 13, 1988

Time: 9:00:58 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8477

Client Project: NYC DEP. W&P# 1079.01.02
5 Beekman

Number of Pages: 3
(including cover page)