

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 7/14/02 4:30:00 AM
ATC Group #: 8492
Analysis Date: 7/14/88

Fax: (212) 922-0630 Phone: (212) 922-0077
Project: NYC DEP, W&P# 1079.01.02
5 Beekman Street, Façade

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
03 8492 -1	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
04 8492 -2	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
05 8492 -3	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
06 8492 -4	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042
07 8492 -5	1350.00	0.0674	0	None Detected	0	0.0042	<14.83	<0.0042

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

PAGE _____ OF _____

P.O. _____

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a

W&P FILE #: 1079-01-02

CONTACT: _____

CLIENT: MYC DEP
PROJECT: FACADE
LOCATION: 5 BEEKMAN ST
8492

LABORATORY:

ANALYSIS METHOD: PCM ~~TEM~~ TEM
circle one 7400 AMERA EPA LEVEL II

TECHNICIAN: FEST / OSEAN CLARK

[illegible]

COMMENTS:

SAMPLE BY: FESTY O'Brien DATE 07-13-02
SIGNATURE: [Signature]
RELEASED BY: _____ DATE: _____
SIGNATURE: _____
RECEIVED BY: ATC Lab [Signature] DATE: 07/14/02
SIGNATURE: [Signature] 04.30

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8492

Fax #: (212) 922-0630

Client Project: NYC DEP, W&P# 1079.01.02
5 Beekman Street, Facade

Date: Thursday, July 14, 1988

Time: 11:29:30 AM

Number of Pages: 3

(including cover page)

Comments: