

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

5 Beekman

Received: 6/19/02

9:00:00 PM

ATC Group #: 8177

Analysis Date: 6/20/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
17 8177 -1	1080.00	0.0787	0	None Detected	0	0	0.0045	<12.71	<0.0045	
18 8177 -2	1080.00	0.4721	0	CHRYSTILE	3	3	0.0045	76.26	0.0272	
19 8177 -3	1080.00	0.0787	0	CHRYSTILE	1	0	0.0045	12.71	0.0045	
20 8177 -4	1080.00	0.0787	0	None Detected	0	0	0.0045	<12.71	<0.0045	
21 8177 -5	1080.00	0.0787	0	CHRYSTILE	1	0	0.0045	12.71	0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0072
Fax (212) 922-0608

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC-DEP
PROJECT: ROOF CLEANING
LOCATION: 5 BEETHAM

W&P FILE #: 1079.01.02

LABORATORY: AFC

ANALYSIS METHOD: PCM TEM
circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: FOYED ELEGENDI

CONTACT: NELSON

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb/cc.)
17	WORK AREA RIGHT	3		3		12:02	18:02	360	1080	
18	WORK AREA LEFT					12:02	18:02			
19	ACCESS TO THE ROOF					12:03	18:03			
20	ONE FLOOR BELOW THE ROOF					12:03	18:03			
21	THE DECK	3		3		12:04	18:04	360	1080	
22	F. BLANK									
23	"									
24	"									

COMMENTS:

#8177

SAMPLE BY: FOYED ELEGENDI DATE: 6.19.02
SIGNATURE: F. Elegendi
RELEASED BY: for DATE: 6.19.02
SIGNATURE: for
RECEIVED BY: AFC Lab / 10/06/02
SIGNATURE: 06 D. KOGAN

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION