

TEL :

Dec 25,00

7:22 No.001 P.10

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel: (212) 704-7000
Fax: (212) 704-0005

CLIENT: Warren & Pitzer Engineers, P.C.

LABORATORY ID #: 702-11-012

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

PROJECT: NYC DEP, 17 Battery Place

DATE OF REPORT: 11/03/02

DATE OF ANALYSIS: 11/03/02

EFFECTIVE FILTER AREA (mm²): 385**LABORATORY RESULTS**

CLIENT #	LAB ID #	LOCATION	VOLUME (M)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (attograms)	TOTAL ASBESTOS AIR CONC. (attograms)	TOTAL ASBESTOS FILTER CONC. (attograms)	AIR CONC. FOR STRUCT. ASSES-5mm	AIR CONC. FOR STRUCT. ASSES-5mm	ASBEST. TYPE CHRYS.	METHOD ASBEST. TYPE SPECIFY
ID01	T02-11-012-3735	IWA right side of W/A	1485	4	0.0537	0.0048	<0.0048	<18.61	NA	NA	NA	NA
ID02	T02-11-012-3736	IWA 3 rd left side of W/A	1485	4	0.0537	0.0048	<0.0048	<18.61	NA	NA	NA	NA
ID03	T02-11-012-3737	IWA 2 nd left side of W/A	1485	4	0.0537	0.0048	<0.0048	<18.61	NA	NA	NA	NA
ID04	T02-11-012-3738	IWA 1 st left side of W/A	1485	4	0.0537	0.0048	<0.0048	<18.61	NA	NA	NA	NA
ID05	T02-11-012-3739	By the doors	1485	4	0.0537	0.0048	<0.0048	<18.61	NA	NA	NA	NA

ANALYST

E. Dimitrakas

LABORATORY DIRECTOR

Spou Domgatis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling results will be stated for any (40) days AES Inc. should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to those tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

TEL:

Dec 25, 00

7:22 No. 001 P. 11

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0636

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

(24 hr⁺/a) 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1
P.O.

CLIENT: NYC DEP

PROJECT: 17 BATTERY PL

LOCATION: FACADE

LABORATORY: W & P
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II

CONTACT: Michael N. L...

TECHNICIAN: Idris Id...

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	ON	TIME OFF	TOTAL TIME	VOLUME (gallons)	CONCENTR. (microg./cc)
1D01	1WA RIGHT SIDE OF WA	3		3	0810	1625	495	1485	
1D02	1WA 3RD LEFT SIDE OF WA	3		3	0812	1627	495	1485	
1D03	1WA 2ND LEFT SIDE OF WA	3		3	0813	1628	495	1485	
1D04	1WA 1ST LEFT SIDE OF WA	3		3	0814	1629	495	1485	
1D05	BT THE DECK	3		3	0815	1630	495	1485	
1D06	Field blank	1		3	N/A				
1D07	Field blank	1			N/A				
1D08	Sealed blank	1			N/A				

COMMENTS:

102-11-012

SAMPLE BY: IDRIS ID... DATE: 11-25-02
 SIGNATURE: [Signature]
 RELEASED BY: IDRIS ID... DATE: 11-25-02
 SIGNATURE: [Signature]
 RECEIVED BY: A. C. HILLARY DATE: 11/3/02
 SIGNATURE: [Signature]

SAMPLE TYPE CODES:

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION