

11/07/2002 18:10 FAX

004

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 704-7490

Fax. (718) 704-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-11-037

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013433

PROJECT: NYC DEP, 17 Battery Place

DATE OF REPORT: 11/07/02

DATE OF ANALYSIS: 11/07/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (H)	G.O. ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struc./cm ²)	TOTAL ASBESTOS AIR CONC. (struc./cm ²)	TOTAL ASBESTOS FILTER CONC. (str./mm ²)	AIR CONC. FOR 0.3-5-9um	AIR CONC. FOR 5-25-9um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
18	T02-11-037-3891	Front yard WA, NW	1480	4	0.0537	0.0048	<0.0047	<18.61	NA	NA	NA	NA
19	T02-11-037-3892	Front yard WA, W	1512	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
20	T02-11-037-3893	Front yard WA, SW	1512	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
21	T02-11-037-3894	Front yard WA, S	1512	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA
22	T02-11-037-3895	Front yard WA, SE	1512	4	0.0537	0.0047	<0.0047	<18.61	NA	NA	NA	NA

ANALYST
E. SionkriLABORATORY DIRECTOR
Spiro Donganis**LABORATORY CERTIFICATION NUMBERS: NVLAP 101956, Z4.AF 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

SEE REVERSE SIDE FOR ANALYSIS INFORMATION