

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Received: 6/27/02

7:00:00 PM

ATC Group #: 8313

Analysis Date: 6/28/02

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

47 Ann Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8313 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8313 -2	1440.00	0.2810	0	CHRYSTOLE	3	2	0.0048	88.97	0.0238
03 8313 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8313 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
05 8313 -5	1440.00	0.1686	0	CHRYSTOLE	1	2	0.0048	53.38	0.0143

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10679

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 622-0077
Fax (212) 622-0630

8313

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____
P.O. _____

CLIENT: DEP
PROJECT: 43A ROOF CLEANUP
LOCATION: 41 AHN-SI

DATE: 12/27
LABORATORY: ATC
ANALYSIS METHOD: PCM
TECHNICIAN: circle one 7400 AHRA EPA LEVEL II

CONTACT: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (mg/cc)
01	ENTRY TO ROOF	3		12:10	12:12	240	1440			
02	DECK	3		12:12	12:14	120	720			
03	CLEARING OF ROOF AND SI	3		12:14	12:15	60	360			
04	DISPOSAL OF ROOF AND SI	3		12:15	12:17	120	720			
05	REMOVAL OF ROOF AND SI	3		12:17	12:18	60	360			
06	FIELD BULK	1								
07	FIELD BULK	1								

COMMENTS:

SAMPLE BY: [Signature] DATE: 12-27
SIGNATURE: _____
RELEASED BY: [Signature] DATE: 12-27
SIGNATURE: _____
RECEIVED BY: _____ DATE: _____
SIGNATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8313

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
47 Ann Street

Date: Monday, July 01, 2002

Time: 10:09:39 PM

Comments:

Number of Pages: 3
(including cover page)

16