

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File # 1079.01.02

47 Ann Street

Received: 7/2/02

5:50:00 PM

ATC Group #: 8382

Analysis Date: 7/3/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ		(S/mm²)	(S/cc)	
JB70202-9 8382 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB70202-1 8382 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB70202-1 8382 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB70202-1 8382 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
JB70202-1 8382 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

PAGE 1 OF 1

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

Time	3 hr ⁺ /a	6 hr ⁺ /a	Immediate ⁺ /a
12 hr ⁺ /o			

CONTACT: Mike Nolan

W&P FILE #: 1079-11.12

LABORATORY:

ANALYSIS METHOD	PCM	TEM	TEM
-----------------	-----	-----	-----

ANALYSIS METHOD: PCM
circle one

TECHNICIAN:

CLIENT: NYCLIFP
PROJECT: 47 ANN ST
LOCATION: 209P

8282

[illegible]

COMMENTS:

SAMPLE BY: John Boyd	DATE: 7-2-02
SIGNATURE: [Signature]	
RELEASED BY: J. Boyd	DATE: 7-2-02
SIGNATURE: [Signature]	
RECEIVED BY: J. Boyd - AIC	DATE: 7/2/02
SIGNATURE: J. Boyd	5:50 PM

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8382

Date: Wednesday, July 03, 2002

Client Project: NYC-DEP W & P File # 1079.01.02
47 Ann Street

Time: 2:40:31 PM

Comments:

Number of Pages: 3
(including cover page)